

# Findings for walkthrough Hammond Middle School: January 23rd, 2019

## (WXXHMS2019000111)

Tracking Number	Finding Type	Comments	Location	Assigned To	Closed
FXXHMS2019000771	Uncomfortable temperature	Uncomfortably cold	Front Office	building	No
FXXHMS2019000773	Artificial plants/trees	Artificial plant	Staff Restroom	administration	Yes
FXXHMS2019000775	Appliances (toaster/coffee maker/fridge/space heaters/air cleaners other than HEPA)	Coffee Pot	Conference Room	administration	Yes
FXXHMS2019000777	Tight seal on ceiling tiles		Health room	custodial	Yes
FXXHMS2019000778	Electrical wiring exposed or disconnected wires	Cable wire along chalk board	131	administration	Yes
FXXHMS201900077A	Electrical cords unsecured, extend across walkways, cord protectors not installed		116	administration	Yes
FXXHMS201900077B	Tight seal on ceiling tiles		145_hall	custodial	Yes
FXXHMS201900077C	Tight seal on ceiling tiles		PE Storage	custodial	Yes
FXXHMS201900077D	Miscellaneous finding	Washer & dryer? & Refrigerator. Are these items used for instruction?	138	administration	Yes