

Findings for walkthrough Wilde Lake Middle School: October 16th, 2019

(WXWLMS2019000219)

Tracking Number	Finding Type	Comments	Location	Assigned To	Closed
FXWLMS20190011F4	Tight seal on ceiling tiles		b18	custodial	Yes
FXWLMS20190011F5	Uncomfortable temperature		a20	building	No
FXWLMS20190011F6	Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress	Slightly blocked wall	249	administration	Yes
FXWLMS20190011F7	Floor coverings not level or secure (tile, carpets, wood board, etc.)	Crack in floor	247	building	No
FXWLMS20190011F9	Floor coverings not level or secure (tile, carpets, wood board, etc.)	Missing baseboard strip on cabinet	a27	building	No
FXWLMS20190011FA	Floor coverings not level or secure (tile, carpets, wood board, etc.)	Exposed metal tile edge on right wall when you enter. Needs new rubber border	245	building	No
FXWLMS20190011FC	Miscellaneous finding	Rust area on floor under vending machine	b12	building	No
FXWLMS20190011FF	Floor coverings not level or secure (tile, carpets, wood board, etc.)	Floor electrical outlets tile is breaking up, have placed several work orders about this issue.	b29	building	No
FXWLMS2019001200	Plumbing fixture leaking/draining slowly	Middle sink needs caulk	253	building	No
FXWLMS2019001202	Tight seal on ceiling tiles		a70	custodial	Yes
FXWLMS2019001203	Floor coverings not level or secure (tile, carpets, wood board, etc.)		a70	building	No
FXWLMS2019001204	Tight seal on ceiling tiles	Ceiling vent needs clean	c08	custodial	Yes
FXWLMS2019001205	Plumbing fixture leaking/draining slowly	Caulk on sinks damaged	Boys 252	building	No
FXWLMS2019001208	Miscellaneous finding	Holiday lights	217	administration	Yes
FXWLMS2019001209	Tight seal on ceiling tiles		a43	custodial	Yes
FXWLMS201900120B	Floor coverings not level or secure (tile, carpets, wood board, etc.)	Crack in cement	240	building	No
FXWLMS201900120C	Tight seal on ceiling tiles	Ceiling vents need clean	c17	custodial	Yes
FXWLMS201900120E	Uncomfortable temperature	Too hot for server	239	building	No
FXWLMS2019001210	Excessive stuffed animals	Many flags covering the entire wall	224	administration	Yes

Tracking Number	Finding Type	Comments	Location	Assigned To	Closed
FXWLMS2019001212	Air freshener/essential oils	No aerosols	Staff br 238	administration	Yes
FXWLMS2019001213	Appliances (toaster/coffee maker/fridge/space heaters/air cleaners other than HEPA)		222	administration	Yes
FXWLMS2019001215	Plumbing fixture leaking/drainning slowly	Caulk on sinks and toilets	220	building	No
FXWLMS2019001216	General Cleanliness/Dust		b27	custodial	Yes