

# Findings for walkthrough Manor Woods Elementary School: October 24th, 2019

## (WXMWES2019000234)

Tracking Number	Finding Type	Comments	Location	Assigned To	Closed
FXMWES201900127D	Excessive stuffed animals		169	administration	Yes
FXMWES201900127E	Plumbing fixture leaking/draining slowly		162	building	Yes
FXMWES201900127F	Excessive stuffed animals		150	administration	Yes
FXMWES2019001280	Signs of insects or evidence of pest		169	building	Yes
FXMWES2019001281	Excessive stuffed animals		B08	administration	Yes
FXMWES2019001282	Excessive stuffed animals		170	administration	Yes
FXMWES2019001283	Chemicals are capped		Office	administration	Yes
FXMWES2019001284	Uncomfortable temperature		B07	building	Yes
FXMWES2019001285	Excessive stuffed animals		B07	administration	Yes
FXMWES2019001286	Excessive stuffed animals		167	administration	Yes
FXMWES2019001287	Excessive stuffed animals		147	administration	Yes
FXMWES2019001288	Excessive stuffed animals		180	administration	Yes
FXMWES2019001289	Excessive stuffed animals		173	administration	Yes
FXMWES201900128A	Appliances (toaster/coffee maker/fridge/space heaters/air cleaners other than HEPA)		173	administration	Yes
FXMWES201900128B	General Cleanliness/Dust		173	custodial	Yes
FXMWES201900128C	General Cleanliness/Dust		181	custodial	Yes
FXMWES201900128D	Plumbing fixture leaking/draining slowly		162	building	Yes
FXMWES201900128E	Excessive stuffed animals		172	administration	Yes
FXMWES201900128F	Tight seal on ceiling tiles		161	custodial	Yes
FXMWES2019001290	Plumbing fixture leaking/draining slowly		BR	building	Yes
FXMWES2019001291	Excessive stuffed animals		175	administration	Yes

Tracking Number	Finding Type	Comments	Location	Assigned To	Closed
FXMWES2019001292	Tight seal on ceiling tiles		153	custodial	Yes
FXMWES2019001293	Miscellaneous finding	Water around sprinkler	153	building	Yes
FXMWES2019001295	Excessive stuffed animals		176	administration	Yes
FXMWES2019001296	Excessive stuffed animals		111	administration	Yes
FXMWES2019001297	General Cleanliness/Dust		176	custodial	Yes
FXMWES2019001298	Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress		153	custodial	Yes
FXMWES2019001299	Artificial plants/trees		111	administration	Yes
FXMWES201900129A	Artificial plants/trees		111	administration	Yes
FXMWES201900129B	Excessive stuffed animals		177	administration	Yes
FXMWES201900129C	Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress		154	custodial	Yes
FXMWES201900129D	Tight seal on ceiling tiles		155	custodial	Yes
FXMWES201900129E	Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress		155	custodial	Yes
FXMWES201900129F	Appliances (toaster/coffee maker/fridge/space heaters/air cleaners other than HEPA)		174	administration	Yes
FXMWES20190012A0	Excessive stuffed animals		174	administration	Yes
FXMWES20190012A1	General Cleanliness/Dust		114	custodial	Yes
FXMWES20190012A2	Excessive stuffed animals		114	administration	Yes
FXMWES20190012A3	Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress		Hall	custodial	Yes
FXMWES20190012A4	General Cleanliness/Dust		178	custodial	Yes
FXMWES20190012A5	Excessive stuffed animals		178	administration	Yes
FXMWES20190012A6	Excessive stuffed animals		146	administration	Yes
FXMWES20190012A7	Exterior doors not fully sealed (daylight)		Gym_156	building	Yes
FXMWES20190012A8	Excessive stuffed animals		179	administration	Yes
FXMWES20190012A9	Elevated moisture per moisture meter		157	building	Yes
FXMWES20190012AA	Excessive stuffed animals		143	administration	Yes
FXMWES20190012AB	Excessive stuffed animals		129	administration	Yes

Tracking Number	Finding Type	Comments	Location	Assigned To	Closed
FXMWES20190012AC	Artificial plants/trees		129	administration	Yes
FXMWES20190012AD	Excessive stuffed animals		139	administration	Yes
FXMWES20190012AE	Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress		139	custodial	Yes
FXMWES20190012AF	Tight seal on ceiling tiles		122	custodial	Yes
FXMWES20190012B0	Electrical cords unsecured, extend across walkways, cord protectors not installed		122	administration	Yes
FXMWES20190012B1	Elevated moisture per moisture meter		122	building	Yes
FXMWES20190012B2	Excessive stuffed animals		101	administration	Yes
FXMWES20190012B3	Excessive stuffed animals		102	administration	Yes
FXMWES20190012B4	Tight seal on ceiling tiles		Hall	custodial	Yes
FXMWES20190012B5	Electrical cords unsecured, extend across walkways, cord protectors not installed	One light not working	Boys toilet	administration	Yes
FXMWES20190012B6	Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress		108	custodial	Yes
FXMWES20190012B7	Excessive stuffed animals		106	administration	Yes
FXMWES20190012B8	Odors	Exhaust not working	Staff restroom	building	Yes
FXMWES20190012B9	Appliances (toaster/coffee maker/fridge/space heaters/air cleaners other than HEPA)		163	administration	Yes
FXMWES20190012BA	Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress		113	custodial	Yes
FXMWES20190012BB	Artificial plants/trees		113	administration	Yes
FXMWES20190012BC	Plumbing fixture leaking/draining slowly		163	custodial	Yes
FXMWES20190012BD	Excessive stuffed animals		115	administration	Yes
FXMWES20190012BE	Excessive stuffed animals		116	administration	Yes
FXMWES20190012BF	Excessive stuffed animals		118	administration	Yes