

Findings for walkthrough Burleigh Manor Middle School: October 29th, 2019

(WXBMMMS2019000238)

Tracking Number	Finding Type	Comments	Location	Assigned To	Closed
FXBMMS2019001348	Tight seal on ceiling tiles		Cafeteria	custodial	Yes
FXBMMS2019001349	Tight seal on ceiling tiles		203	custodial	Yes
FXBMMS201900134A	Tight seal on ceiling tiles		204	custodial	Yes
FXBMMS201900134B	Tight seal on ceiling tiles		hallway_195	custodial	Yes
FXBMMS201900134C	Tight seal on ceiling tiles		hallway_195	custodial	Yes
FXBMMS201900134D	General Cleanliness/Dust		Stairwell	custodial	Yes
FXBMMS201900134E	General Cleanliness/Dust		Vestibule	custodial	Yes
FXBMMS201900134F	Tight seal on ceiling tiles		130	custodial	Yes
FXBMMS2019001351	Tight seal on ceiling tiles		129	custodial	Yes
FXBMMS2019001352	Tight seal on ceiling tiles		128	custodial	Yes
FXBMMS2019001353	Miscellaneous finding	Light fixture not properly placed	128	building	No
FXBMMS2019001354	General Cleanliness/Dust		hallway_153	custodial	Yes
FXBMMS2019001355	Artificial plants/trees	Artificial tree	121 closet	administration	Yes
FXBMMS2019001357	Artificial plants/trees	Some plants do not have a water barrier	120	administration	Yes
FXBMMS2019001359	Appliances (toaster/coffee maker/fridge/space heaters/air cleaners other than HEPA)	Mini fridge	117	administration	Yes
FXBMMS201900135B	Excessive stuffed animals		146	administration	Yes
FXBMMS201900135C	Appliances (toaster/coffee maker/fridge/space heaters/air cleaners other than HEPA)	Mini fridge & coffee maker	115	administration	Yes
FXBMMS201900135F	Tight seal on ceiling tiles		Health Storage Room	custodial	Yes
FXBMMS2019001361	Miscellaneous finding	Bathrooms smell. The exhaust does not appear to be working.	Boys & Girls Rooms Next to Room 230	building	No