Findings for walkthrough Thunder Hill Elementary School: November 7th, 2022 (WXTHES2022000406)

Tracking Number	Finding Type	Comments	Location	Assigned To	Closed
FXTHES202200205A	Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress	The supply diffusers are visibly dirty and require dusting/cleaning.	Administration	custodial	Yes
FXTHES202200205B	Air freshener/essential oils	Strong air freshener odor wit air freshener located on desk. Remind staff air fresheners, plug-ins, scent oil sticks, etc. are not permitted because they can mask an odor of concern and/or be an irritant to other individuals.	Room 127	administration	Yes
FXTHES202200205C	Non-issued disinfectants/aerosol sprays	An aerosol disinfectant spray was observed within classroom. Such products are not permitted since they can be an airborne irritant when used. Disinfectant wipes and/or the approved cleaning solution from Custodial are permitted.	Room 127	administration	Yes
FXTHES202200205D	Artificial plants/trees	Artificial plants easily collect dust (potential allergen) and are difficult to clean. This item is to be removed.	Room 123	administration	Yes
FXTHES202200205E	Signs of insects or evidence of pest	Food product readily accessible to pests. Place food item in a durable and sealable container.	Room 206 - Storage	administration	Yes
FXTHES202200205F	Stained/damaged tiles	Water stained ceiling tile. If not already being addressed, school custodial staff is to submit a work order to Building Maintenance to evaluate, correct source, and replace ceiling tile.	Room 120	custodial	Yes
FXTHES2022002060	Stained/damaged tiles	Water stained ceiling tile. If not already being addressed, school custodial staff is to submit a work order to Building Maintenance to evaluate, correct source, and replace ceiling tile.	Room 113	custodial	Yes
FXTHES2022002061	Tight seal on ceiling tiles	Ceiling tile askew. Reset well onsite, no further action required.	Room 213	environmental	Yes
FXTHES2022002062	Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress	The supply diffusers are visibly dirty and require dusting/cleaning.	Room 313	custodial	Yes
FXTHES2022002063	Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress	The supply diffusers are visibly dirty and require dusting/cleaning.	Outside 214	custodial	Yes

Tracking Number	Finding Type	Comments	Location	Assigned To	Closed
FXTHES2022002064 M	Miscellaneous finding	The thermostat guards were either off or not fully adhered. Please remind teachers not to adjust thermostat settings, as incorrect settings can cause mold growth, particularly in the summer. If guards are damaged and cannot be replaced, place work order for Building Maintenance to replace the guards.	Portable 211 and 213	administration	Yes
FXTHES2022002065 N	Miscellaneous finding	The thermostat is indicating "Replace Battery."	Portable 211	building	Yes