

Findings for walkthrough Marriotts Ridge High School: November 30th, 2018

(WXMLRHS20180000AF)

| Tracking Number | Finding Type | Comments | Location | Assigned To | Closed |
|------------------|--|-------------------------------|-------------------------------------|----------------|--------|
| FXMRHS20180002D9 | Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress | Supply diffusers | cafeteria | administration | Yes |
| FXMRHS20180002DB | Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress | Dirty return over dishwasher | Kitchen | administration | Yes |
| FXMRHS20180002DD | General Cleanliness/Dust | | Telecommunications | custodial | Yes |
| FXMRHS20180002DE | Excessive stuffed animals | Several offices with curtains | Admin | administration | Yes |
| FXMRHS20180002E0 | Appliances (toaster/coffee maker/fridge/space heaters/air cleaners other than HEPA) | | Guidance Office | administration | Yes |
| FXMRHS20180002E1 | Miscellaneous finding | Missing escutcheon plate | Guidance | | No |
| FXMRHS20180002E5 | Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress | Supply diffuser | 125 | administration | Yes |
| FXMRHS20180002E7 | Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress | Supply diffuser dirty | 126 | administration | Yes |
| FXMRHS20180002E9 | General Cleanliness/Dust | Clutter | Art Office | custodial | Yes |
| FXMRHS20180002EB | Tight seal on ceiling tiles | | 120 | custodial | Yes |
| FXMRHS20180002EC | Electrical cords unsecured, extend across walkways, cord protectors not installed | | Asst Principal -Foyles | administration | Yes |
| FXMRHS20180002ED | Tight seal on ceiling tiles | | 117 | custodial | Yes |
| FXMRHS20180002EE | Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress | Supply diffusers dirty | Sports equipment room off of health | administration | Yes |
| FXMRHS20180002F0 | Electrical cords unsecured, extend across walkways, cord protectors not installed | | Asst Principal -Foyles closet | administration | Yes |
| FXMRHS20180002F1 | Tight seal on ceiling tiles | | 246 | custodial | Yes |
| FXMRHS20180002F2 | Tight seal on ceiling tiles | | Boys locker room office | custodial | Yes |

| Tracking Number | Finding Type | Comments | Location | Assigned To | Closed |
|------------------|--|-------------------------|-----------------------|----------------|--------|
| FXMRHS20180002F3 | General Cleanliness/Dust | | 246 | custodial | Yes |
| FXMRHS20180002F4 | Tight seal on ceiling tiles | | Chem Storage Room | custodial | Yes |
| FXMRHS20180002F5 | Tight seal on ceiling tiles | | 240 | custodial | Yes |
| FXMRHS20180002F6 | Tight seal on ceiling tiles | Water stains on 2 tiles | 336 | custodial | Yes |
| FXMRHS20180002F7 | Tight seal on ceiling tiles | | 238 | custodial | Yes |
| FXMRHS20180002F8 | Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress | | 105 Storage | administration | Yes |
| FXMRHS20180002F9 | Tight seal on ceiling tiles | | 105 | custodial | Yes |
| FXMRHS20180002FA | Tight seal on ceiling tiles | In and outside of room | 102 | custodial | Yes |
| FXMRHS20180002FB | Tight seal on ceiling tiles | | 102 | custodial | Yes |
| FXMRHS20180002FD | Artificial plants/trees | | Health | administration | Yes |
| FXMRHS20180002FE | Tight seal on ceiling tiles | | Corner hallway | custodial | Yes |
| FXMRHS20180002FF | Excessive stuffed animals | Curtains | 342 | administration | Yes |
| FXMRHS2018000300 | Tight seal on ceiling tiles | | 224 | custodial | Yes |
| FXMRHS2018000301 | Tight seal on ceiling tiles | Side entrance | auditorium_hall-2 | custodial | Yes |
| FXMRHS2018000303 | Tight seal on ceiling tiles | | Outside Police Office | custodial | Yes |
| FXMRHS2018000304 | Excessive stuffed animals | Stuffed animals | 312 | administration | Yes |
| FXMRHS2018000305 | Electrical cords unsecured, extend across walkways, cord protectors not installed | Cord blocking walkway | 322 | administration | Yes |
| FXMRHS2018000306 | Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress | | 322 | administration | Yes |
| FXMRHS2018000307 | Tight seal on ceiling tiles | | Computer Lab | custodial | Yes |
| FXMRHS2018000308 | Electrical cords unsecured, extend across walkways, cord protectors not installed | Cords blocking walkway | 323 | administration | Yes |
| FXMRHS2018000309 | Uncomfortable temperature | Very warm all day | 326 | building | No |
| FXMRHS201800030A | Tight seal on ceiling tiles | | Media Production | custodial | Yes |