

Findings for walkthrough Marriotts Ridge High School: November 30th, 2018 (WXMRHS20180000AF)

Tracking Number	Finding Type	Comments	Location	Assigned To	Closed
FXMRHS20180002D9	Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress	Supply diffusers	cafeteria	administration	Yes
FXMRHS20180002DB	Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress	Dirty return over dishwasher	Kitchen	administration	Yes
FXMRHS20180002DD	General Cleanliness/Dust		Telecommunications	custodial	Yes
FXMRHS20180002DE	Excessive stuffed animals	Several offices with curtains	Admin	administration	Yes
FXMRHS20180002E0	Appliances (toaster/coffee maker/fridge/space heaters/air cleaners other than HEPA)		Guidance Office	administration	Yes
FXMRHS20180002E1	Miscellaneous finding	Missing escutcheon plate	Guidance		No
FXMRHS20180002E5	Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress	Supply diffuser	125	administration	Yes
FXMRHS20180002E7	Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress	Supply diffuser dirty	126	administration	Yes
FXMRHS20180002E9	General Cleanliness/Dust	Clutter	Art Office	custodial	Yes
FXMRHS20180002EB	Tight seal on ceiling tiles		120	custodial	Yes
FXMRHS20180002EC	Electrical cords unsecured, extend across walkways, cord protectors not installed		Asst Principal -Foyles	administration	Yes
FXMRHS20180002ED	Tight seal on ceiling tiles		117	custodial	Yes
FXMRHS20180002EE	Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress	Supply diffusers dirty	Sports equipment room off of health	administration	Yes
FXMRHS20180002F0	Electrical cords unsecured, extend across walkways, cord protectors not installed		Asst Principal -Foyles closet	administration	Yes
FXMRHS20180002F1	Tight seal on ceiling tiles		246	custodial	Yes
FXMRHS20180002F2	Tight seal on ceiling tiles		Boys locker room office	custodial	Yes

Tracking Number	Finding Type	Comments	Location	Assigned To	Closed
FXMRHS20180002F3	General Cleanliness/Dust		246	custodial	Yes
FXMRHS20180002F4	Tight seal on ceiling tiles		Chem Storage Room	custodial	Yes
FXMRHS20180002F5	Tight seal on ceiling tiles		240	custodial	Yes
FXMRHS20180002F6	Tight seal on ceiling tiles	Water stains on 2 tiles	336	custodial	Yes
FXMRHS20180002F7	Tight seal on ceiling tiles		238	custodial	Yes
FXMRHS20180002F8	Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress		105 Storage	administration	Yes
FXMRHS20180002F9	Tight seal on ceiling tiles		105	custodial	Yes
FXMRHS20180002FA	Tight seal on ceiling tiles	In and outside of room	102	custodial	Yes
FXMRHS20180002FB	Tight seal on ceiling tiles		102	custodial	Yes
FXMRHS20180002FD	Artificial plants/trees		Health	administration	Yes
FXMRHS20180002FE	Tight seal on ceiling tiles		Corner hallway	custodial	Yes
FXMRHS20180002FF	Excessive stuffed animals	Curtains	342	administration	Yes
FXMRHS2018000300	Tight seal on ceiling tiles		224	custodial	Yes
FXMRHS2018000301	Tight seal on ceiling tiles	Side entrance	auditorium_hall-2	custodial	Yes
FXMRHS2018000303	Tight seal on ceiling tiles		Outside Police Office	custodial	Yes
FXMRHS2018000304	Excessive stuffed animals	Stuffed animals	312	administration	Yes
FXMRHS2018000305	Electrical cords unsecured, extend across walkways, cord protectors not installed	Cord blocking walkway	322	administration	Yes
FXMRHS2018000306	Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress		322	administration	Yes
FXMRHS2018000307	Tight seal on ceiling tiles		Computer Lab	custodial	Yes
FXMRHS2018000308	Electrical cords unsecured, extend across walkways, cord protectors not installed	Cords blocking walkway	323	administration	Yes
FXMRHS2018000309	Uncomfortable temperature	Very warm all day	326	building	No
FXMRHS201800030A	Tight seal on ceiling tiles		Media Production	custodial	Yes