

# Findings for walkthrough Oakland Mills Middle School: December 4th, 2018 (WXOMMS20180000B3)

Tracking Number	Finding Type	Comments	Location	Assigned To	Closed
FXOMMS201800031A	Miscellaneous finding	Possible occupant discomfort. Foil on diffuser	50		No
FXOMMS201800031C	Miscellaneous finding		130	administration	Yes
FXOMMS201800031D	Appliances (toaster/coffee maker/fridge/space heaters/air cleaners other than HEPA)	Area rug - HCPSS approved?	43	administration	Yes
FXOMMS201800031F	Signs of insects or evidence of pest	Spider webs	4	building	No
FXOMMS2018000322	Tight seal on ceiling tiles		028	custodial	Yes
FXOMMS2018000323	Artificial plants/trees		40	administration	Yes
FXOMMS2018000324	Air freshener/essential oils	Incense	33	administration	Yes
FXOMMS2018000326	Miscellaneous finding	Crack in wall above interior windows	5		No
FXOMMS2018000327	Tight seal on ceiling tiles	Holes in tiles	339	custodial	Yes
FXOMMS201800032A	Signs of insects or evidence of pest	Spider webs along interior electrical on exterior walls and near exterior door	7	building	No
FXOMMS201800032B	Windows/Doors open	Exterior door doesn't fully close	7	administration	Yes
FXOMMS201800032C	Miscellaneous finding	Brown spots on electrical on back wall	7		No
FXOMMS201800032E	Windows/Doors open	Broken window far left back wall	7	building	No
FXOMMS201800032F	Signs of insects or evidence of pest	Spider webs in corners	11	building	No
FXOMMS2018000330	Miscellaneous finding	Hallway running next to cafeteria - missing escutcheon plate.	cafeteria		No
FXOMMS2018000333	Tight seal on ceiling tiles	Cracked tile	11	custodial	Yes
FXOMMS2018000334	Exterior doors not fully sealed (daylight)	At cafeteria double doors to exterior	cafeteria	building	No
FXOMMS2018000335	Tight seal on ceiling tiles		70	custodial	Yes
FXOMMS2018000337	Miscellaneous finding	Corner near Windows is dusty with cracked tile frame	18		No

Tracking Number	Finding Type	Comments	Location	Assigned To	Closed
FXOMMS2018000338	Tight seal on ceiling tiles		70	custodial	Yes
FXOMMS201800033A	Miscellaneous finding	Rust on supply diffuser. Place work for order.	Kitchen office		No
FXOMMS201800033C	Signs of insects or evidence of pest	Spider webs in windows	18	building	No
FXOMMS201800033D	Miscellaneous finding	Rusty supply diffusers throughout kitchen area	227		No
FXOMMS201800033E	Miscellaneous finding		227		No
FXOMMS201800033F	Signs of insects or evidence of pest	Spider webs in corners	21	building	No
FXOMMS2018000341	Holes/Penetrations in Wall	Cracks along whole left wall	21	building	No
FXOMMS2018000343	Tight seal on ceiling tiles	Dirty vent	75	custodial	Yes
FXOMMS2018000344	Tight seal on ceiling tiles		12_hall	custodial	Yes
FXOMMS2018000345	Miscellaneous finding	Crack in wall outside room 22	12_hall		No
FXOMMS2018000346	Tight seal on ceiling tiles		79	custodial	Yes
FXOMMS2018000347	Tight seal on ceiling tiles	Dust on vent	79	custodial	Yes
FXOMMS2018000348	Tight seal on ceiling tiles		22	custodial	Yes
FXOMMS2018000349	Miscellaneous finding	Peeling paint near return	Boys bath near cafe		No
FXOMMS201800034B	Miscellaneous finding	Crack above door to class 20 Crack above door to hallway	22		No
FXOMMS201800034C	Holes/Penetrations in Wall	Crack near windows	22	building	No
FXOMMS201800034D	Tight seal on ceiling tiles	Ceiling tile dislodged.	45	custodial	Yes
FXOMMS2018000350	Miscellaneous finding	Crack on wall above locker 478	12_hall		No
FXOMMS2018000352	Tight seal on ceiling tiles	Dusty vent	86	custodial	Yes
FXOMMS2018000354	Miscellaneous finding	Crack outside door to room 13	12_hall		No
FXOMMS2018000355	Tight seal on ceiling tiles		13	custodial	Yes
FXOMMS2018000356	Tight seal on ceiling tiles	Dust vent	85	custodial	Yes
FXOMMS2018000357	Miscellaneous finding	Walls are separated from ceiling	13		No
FXOMMS2018000358	Tight seal on ceiling tiles	Stained tile above locker 456	12_hall	custodial	Yes
FXOMMS2018000359	Tight seal on ceiling tiles	Planes on ceilings Water stain	87	custodial	Yes

<b>Tracking Number</b>	<b>Finding Type</b>	<b>Comments</b>	<b>Location</b>	<b>Assigned To</b>	<b>Closed</b>
FXOMMS201800035A	Miscellaneous finding	Crack in wall outside door to room 12	12_hall		No
FXOMMS201800035B	Tight seal on ceiling tiles		9	custodial	Yes
FXOMMS201800035C	Miscellaneous finding	Cracks in wall above interior windows	9		No
FXOMMS201800035D	Tight seal on ceiling tiles	Missing triangular tiles near exterior door outside room 2	12_hall	custodial	Yes
FXOMMS201800035E	Tight seal on ceiling tiles		14	custodial	Yes
FXOMMS201800035F	General Cleanliness/Dust	Dusty ceiling vent	14	custodial	Yes
FXOMMS2018000360	Miscellaneous finding	Crack above door	19		No
FXOMMS2018000361	Miscellaneous finding	Crack on left side of back wall	19		No
FXOMMS2018000362	Miscellaneous finding	Crack near beam across from room 19	24_hall		No
FXOMMS2018000363	Miscellaneous finding	Crack on wall to left of entrance	20		No
FXOMMS2018000364	Miscellaneous finding	Cracks above door	20		No
FXOMMS2018000365	Miscellaneous finding	Crack above door to room 23	20		No
FXOMMS2018000366	Miscellaneous finding	Crack on back wall left side	20		No
FXOMMS2018000368	Miscellaneous finding	Crack above door to next room	23		No
FXOMMS2018000369	Miscellaneous finding	Wall separated from ceiling	127		No
FXOMMS201800036A	Miscellaneous finding	Rusty vents	24_hall		No
FXOMMS201800036B	Tight seal on ceiling tiles		24_hall	custodial	Yes
FXOMMS201800036C	Tight seal on ceiling tiles		101 Gym Storage	custodial	Yes
FXOMMS201800036D	Tight seal on ceiling tiles		105 Gym Storage	custodial	Yes
FXOMMS201800036E	Tight seal on ceiling tiles	Stained tile outside door	Boys bathroom	custodial	Yes
FXOMMS201800036F	Tight seal on ceiling tiles	Stained tile above projector screen	10	custodial	Yes
FXOMMS2018000370	Miscellaneous finding	Crack above door to room 6	10		No
FXOMMS2018000371	Tight seal on ceiling tiles	Near room 3	33_hall	custodial	Yes
FXOMMS2018000372	Miscellaneous finding	Crack above door to hallway	33_hall		No