

# Findings for walkthrough Bryant Woods Elementary School: July 10th, 2023 (WXBWES2023000472)

Tracking Number	Finding Type	Comments	Location	Assigned To	Closed
FXBWES20230023C8	Miscellaneous finding	Thermostat blank and the guard front cover missing.	Computer Lab 123	building	Yes
FXBWES20230023C9	Miscellaneous finding	Thermostat set at 73 degrees Fahrenheit (F) instead of 82 degrees F, per the Summer HVAC operation schedule.	Portable # 113	building	Yes
FXBWES20230023CA	Miscellaneous finding	Thermostat set at 73 degrees Fahrenheit (F) instead of 82 degrees F, per the Summer HVAC operation schedule.	Portable # 234	building	Yes
FXBWES20230023FE	Stained/damaged tiles	Water stained ceiling tile. If not already being addressed, school custodial staff is to submit a work order to Building Maintenance to evaluate, correct source, and replace ceiling tile.	Work Room 153	custodial	Yes
FXBWES20230023FF	Miscellaneous finding	Air purifier running with no occupants during summer vacation. Turn off air purifier to conserve energy.	Computer Lab 123	custodial	Yes
FXBWES2023002400	Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress	The return grille is visibly dirty and require dusting/cleaning.	Restroom near CR# 110	custodial	Yes
FXBWES2023002401	Miscellaneous finding	Space temperature 70.9 degrees F, which is below the HCPSS standard temperature set point of 76 deg. F, and being overcooled.	Classroom 136	building	Yes
FXBWES2023002402	Miscellaneous finding	Space temperature 74.3 degrees F, below the HCPSS temperature standard.	Classroom # 128	building	Yes
FXBWES2023002403	Miscellaneous finding	Thermostat set at 72 degrees F instead of 82 degrees F, per the Summer HVAC operation schedule.	Portable # 118	building	Yes
FXBWES2023002404	Miscellaneous finding	Thermostat set at 73 degrees F instead of 82 degrees F, per the Summer HVAC operation schedule.	Portables # 258	building	Yes
FXBWES2023002405	Miscellaneous finding	Space temperature 73 degrees F, below the HCPSS temperature standard of 76 degrees F set point and being overcooled.	Health Office Room # 155	building	Yes

Tracking Number	Finding Type	Comments	Location	Assigned To	Closed
FXBWES2023002406	Miscellaneous finding	The air conditioning is running in most of the areas of the building during the day, during the summer vacation. In summer, air conditioning is supposed to run only from 4 pm to 6 pm on weekdays if there's no summer school, summer camp, and/or if custodial requested. Building Maintenance is to review the operations schedule for the school.	Throughout The Building	building	Yes