

Findings for walkthrough Bryant Woods Elementary School: July 10th, 2023 (WXBWES2023000472)

| Tracking Number | Finding Type | Comments | Location | Assigned To | Closed |
|------------------|--|---|--------------------------|-------------|--------|
| FXBWES20230023C8 | Miscellaneous finding | Thermostat blank and the guard front cover missing. | Computer Lab 123 | building | Yes |
| FXBWES20230023C9 | Miscellaneous finding | Thermostat set at 73 degrees Fahrenheit (F) instead of 82 degrees F, per the Summer HVAC operation schedule. | Portable # 113 | building | Yes |
| FXBWES20230023CA | Miscellaneous finding | Thermostat set at 73 degrees Fahrenheit (F) instead of 82 degrees F, per the Summer HVAC operation schedule. | Portable # 234 | building | Yes |
| FXBWES20230023FE | Stained/damaged tiles | Water stained ceiling tile. If not already being addressed, school custodial staff is to submit a work order to Building Maintenance to evaluate, correct source, and replace ceiling tile. | Work Room 153 | custodial | Yes |
| FXBWES20230023FF | Miscellaneous finding | Air purifier running with no occupants during summer vacation. Turn off air purifier to conserve energy. | Computer Lab 123 | custodial | Yes |
| FXBWES2023002400 | Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress | The return grille is visibly dirty and require dusting/cleaning. | Restroom near CR# 110 | custodial | Yes |
| FXBWES2023002401 | Miscellaneous finding | Space temperature 70.9 degrees F, which is below the HCPSS standard temperature set point of 76 deg. F, and being overcooled. | Classroom 136 | building | Yes |
| FXBWES2023002402 | Miscellaneous finding | Space temperature 74.3 degrees F, below the HCPSS temperature standard. | Classroom # 128 | building | Yes |
| FXBWES2023002403 | Miscellaneous finding | Thermostat set at 72 degrees F instead of 82 degrees F, per the Summer HVAC operation schedule. | Portable # 118 | building | Yes |
| FXBWES2023002404 | Miscellaneous finding | Thermostat set at 73 degrees F instead of 82 degrees F, per the Summer HVAC operation schedule. | Portables # 258 | building | Yes |
| FXBWES2023002405 | Miscellaneous finding | Space temperature 73 degrees F, below the HCPSS temperature standard of 76 degrees F set point and being overcooled. | Health Office Room # 155 | building | Yes |

| Tracking Number | Finding Type | Comments | Location | Assigned To | Closed |
|------------------|-----------------------|---|----------------------------|-------------|--------|
| FXBWES2023002406 | Miscellaneous finding | The air conditioning is running in most of the areas of the building during the day, during the summer vacation. In summer, air conditioning is supposed to run only from 4 pm to 6 pm on weekdays if there's no summer school, summer camp, and/or if custodial requested. Building Maintenance is to review the operations schedule for the school. | Throughout The Building | building | Yes |