

# Findings for walkthrough Jeffers Hill Elementary School: July 21st, 2023

## (WXJHES2023000477)

Tracking Number	Finding Type	Comments	Location	Assigned To	Closed
FXJHES2023002429	Uncomfortable temperature	Air conditioning running earlier in the day in the entire section and maintaining 74.6 deg. and being overcooled while it is unoccupied during summer vacation. In summer, air conditioning is supposed to run only from 4 pm to 6 pm on weekdays and maintain 76 deg. There's no summer camp in this section of the building unless it's a custodial request. Building Maintenance is to review the HVAC operations schedule for the school and temperature settings.	Media Center	building	Yes
FXJHES202300242A	Uncomfortable temperature	Space temperature 73.8 deg. overcooling and below the standard of HCPSS Guidelines for Energy Conservation setting of 76 deg. for cooling mode.	Art 093	building	Yes
FXJHES202300242B	Miscellaneous finding	Fire extinguisher inspection two months behind. Last inspected in May 2023.	Hallway near Storage 012	custodial	Yes
FXJHES202300242C	Miscellaneous finding	Broken ceiling tile needs to be replaced.	Teachers Lounge	custodial	Yes