

Findings for walkthrough Worthington Elementary School: July 31st, 2023 (WXWOES202300047D)

Tracking Number	Finding Type	Comments	Location	Assigned To	Closed
FXWOES2023002478	Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress	Supply diffusers dusty. Custodial to remind high dusting crew to dust during their next scheduled visit.	Cafeteria	custodial	Yes
FXWOES2023002479	Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress	The supply diffusers are visibly dirty and require dusting/cleaning.	190	custodial	Yes
FXWOES202300247A	Miscellaneous finding	Carpet ripped.	190	building	Yes
FXWOES202300247B	Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress	The supply diffusers are visibly dirty and require dusting/cleaning.	191	custodial	Yes
FXWOES202300247C	Stained/damaged tiles	Water stained ceiling tile. If not already being addressed, school custodial staff is to submit a work order to Building Maintenance to evaluate, correct source, and replace ceiling tile.	Outside 193	custodial	Yes
FXWOES202300247D	Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress	The supply diffusers are visibly dirty and require dusting/cleaning.	196	custodial	Yes
FXWOES202300247E	Stained/damaged tiles	Heavy ceiling tile staining, floor cleaning needed from leak. If not already being addressed, school custodial staff is to submit a work order to Building Maintenance to evaluate, correct source, and replace ceiling tile.	Outside 167	custodial	Yes
FXWOES202300247F	Holes/Penetrations in Wall	Bubbling paint near exterior door.	140	building	Yes
FXWOES2023002480	Signs of insects or evidence of pest	Evidence of ants at exterior door.	135	building	Yes
FXWOES2023002481	Stained/damaged tiles	Water stained ceiling tile. If not already being addressed, school custodial staff is to submit a work order to Building Maintenance to evaluate, correct source, and replace ceiling tile.	Outside 125	custodial	Yes

Tracking Number	Finding Type	Comments	Location	Assigned To	Closed
FXWOES2023002482	Stained/damaged tiles	Water stained ceiling tile. If not already being addressed, school custodial staff is to submit a work order to Building Maintenance to evaluate, correct source, and replace ceiling tile.	155B	custodial	Yes
FXWOES2023002483	Stained/damaged tiles	Water stained ceiling tiles (multiple). If not already being addressed, school custodial staff is to submit a work order to Building Maintenance to evaluate, correct source, and replace ceiling tile.	117	custodial	Yes