

Findings for walkthrough Worthington Elementary School: July 31st, 2023 (WXWOES202300047D)

| Tracking Number | Finding Type | Comments | Location | Assigned To | Closed |
|------------------|--|---|-------------|-------------|--------|
| FXWOES2023002478 | Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress | Supply diffusers dusty. Custodial to remind high dusting crew to dust during their next scheduled visit. | Cafeteria | custodial | Yes |
| FXWOES2023002479 | Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress | The supply diffusers are visibly dirty and require dusting/cleaning. | 190 | custodial | Yes |
| FXWOES202300247A | Miscellaneous finding | Carpet ripped. | 190 | building | Yes |
| FXWOES202300247B | Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress | The supply diffusers are visibly dirty and require dusting/cleaning. | 191 | custodial | Yes |
| FXWOES202300247C | Stained/damaged tiles | Water stained ceiling tile. If not already being addressed, school custodial staff is to submit a work order to Building Maintenance to evaluate, correct source, and replace ceiling tile. | Outside 193 | custodial | Yes |
| FXWOES202300247D | Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress | The supply diffusers are visibly dirty and require dusting/cleaning. | 196 | custodial | Yes |
| FXWOES202300247E | Stained/damaged tiles | Heavy ceiling tile staining, floor cleaning needed from leak. If not already being addressed, school custodial staff is to submit a work order to Building Maintenance to evaluate, correct source, and replace ceiling tile. | Outside 167 | custodial | Yes |
| FXWOES202300247F | Holes/Penetrations in Wall | Bubbling paint near exterior door. | 140 | building | Yes |
| FXWOES2023002480 | Signs of insects or evidence of pest | Evidence of ants at exterior door. | 135 | building | Yes |
| FXWOES2023002481 | Stained/damaged tiles | Water stained ceiling tile. If not already being addressed, school custodial staff is to submit a work order to Building Maintenance to evaluate, correct source, and replace ceiling tile. | Outside 125 | custodial | Yes |

| Tracking Number | Finding Type | Comments | Location | Assigned To | Closed |
|------------------------|-----------------------|---|-----------------|--------------------|---------------|
| FXWOES2023002482 | Stained/damaged tiles | Water stained ceiling tile. If not already being addressed, school custodial staff is to submit a work order to Building Maintenance to evaluate, correct source, and replace ceiling tile. | 155B | custodial | Yes |
| FXWOES2023002483 | Stained/damaged tiles | Water stained ceiling tiles (multiple). If not already being addressed, school custodial staff is to submit a work order to Building Maintenance to evaluate, correct source, and replace ceiling tile. | 117 | custodial | Yes |