

Findings for walkthrough River Hill High School: August 8th, 2023 (WXRHHS2023000485)

| Tracking Number | Finding Type | Comments | Location | Assigned To | Closed |
|------------------|-----------------------------|--|-----------------------------------|-------------|--------|
| FXRHHS20230024D5 | Tight seal on ceiling tiles | Several ceiling tiles removed. Ensure concern is addressed if any and reinstall the tiles. | Locker Room in Kitchen | custodial | Yes |
| FXRHHS20230024FF | Tight seal on ceiling tiles | A few ceiling tiles missing. Ensure concern is addressed if any and reinstall the tiles. | Dishwashing Area | custodial | Yes |
| FXRHHS2023002500 | Miscellaneous finding | Space temperature 72.4 deg. Air conditioning running earlier in the day in most of the areas of the building while they are unoccupied during the summer vacation and overcooling the spaces below the HCPSS Guidelines for Energy Conservation setting of 76 deg. for cooling. Plus, per the Memorandum, in summer, air conditioning is supposed to run only from 4 pm to 6 pm on weekdays if there's no summer school, summer camp, and/or if custodial requested. Building Maintenance HVAC Department is to review the HVAC operations schedule for the school and temperature set point. | Classroom # 256 | building | Yes |
| FXRHHS2023002501 | Miscellaneous finding | Space overcooling down to 66.7 deg. that is ten degrees below the HCPSS Guidelines for Energy Conservation setting of 76 deg. for cooling. Air conditioning running earlier in the day in most of the areas of the building while they are unoccupied during the summer vacation. Per the Memorandum, in summer, air conditioning is supposed to run only from 4 pm to 6 pm on weekdays if there's no summer school, summer camp, and/or if custodial requested. Building Maintenance HVAC Department is to review the HVAC operations schedule for the school and temperature set point. | Open Area near Auditorium | building | Yes |
| FXRHHS2023002521 | Miscellaneous finding | Most of the unoccupied areas maintaining space temperature between 71 deg. and 73 deg. Air conditioning running earlier in the day in most of the areas of the building while they are unoccupied during the summer vacation and overcooling the spaces below the HCPSS Guidelines for Energy Conservation setting of 76 deg. for cooling. Plus, per the Memorandum, in summer, air conditioning is supposed to run only from 4 pm to 6 pm on weekdays if there's no summer school, summer camp, and/or if custodial requested. Building Maintenance HVAC Department is to review the HVAC operations schedule for the school and temperature set point. | Majority of the unoccupied spaces | building | Yes |