

Findings for walkthrough Ducketts Lane Elementary School: August 14th, 2023 (WXDLES202300048E)

Tracking Number	Finding Type	Comments	Location	Assigned To	Closed
FXDLES2023002577	18" Of Clearance from Ceiling	Miscellaneous items stored on top of shelves less than 18 inches from the ceiling. Remove/reconfigure to comply with Fire Code.	Classroom # A135	administration	Yes
FXDLES2023002578	18" Of Clearance from Ceiling	Miscellaneous items stored less than 18 inches from the ceiling. Remove/reconfigure to comply with Fire Code.	Computer B118	administration	Yes
FXDLES2023002579	18" Of Clearance from Ceiling	Miscellaneous items stored less than 18 inches from the ceiling. Remove/reconfigure to comply with Fire Code.	Extended Learning C127	administration	Yes
FXDLES202300257A	Miscellaneous finding	Lights do not appear to be working. Place a work order if one is not already in place.	Custodial Storage C114A	custodial	Yes
FXDLES202300257B	Miscellaneous finding	Space temperature 72.2. deg. overcooling. The temperature are several degrees below the standard of HCPSS Guidelines for Energy Conservation setting of 76 deg. for cooling mode. Building Maintenance to review the HVAC controls and temperature settings for the school to improve energy conservation.	Staff Lounge	building	Yes
FXDLES2023002591	Miscellaneous finding	Majority of the areas in the building are being overcooled into the low 70 deg. The temperature are several degrees below the standard of HCPSS Guidelines for Energy Conservation setting of 76 deg. for cooling mode. Building Maintenance to review the HVAC controls and temperature settings for the school to improve energy conservation.	Throughout the Building	building	Yes