

# Findings for walkthrough Stevens Forest Elementary School: August 15th, 2023

## (WXSFE2023000490)

Tracking Number	Finding Type	Comments	Location	Assigned To	Closed
FXSFES2023002592	Miscellaneous finding	Fire extinguisher behind monthly inspection. Last inspected in May 2023. Perform monthly.	Hallway near front office	custodial	Yes
FXSFES2023002597	Miscellaneous finding	Fire extinguisher behind monthly inspection. Last inspected in October 2022. Perform monthly.	Portable # 105	custodial	Yes
FXSFES2023002598	Miscellaneous finding	Heating and ventilation unit running while it's not occupied during summer break. Appears to be bringing in hot and humid air from outside and making the gym even more uncomfortable. Building Maintenance to review the HVAC controls and schedule settings to ensure units are not running during summer while gym is not occupied.	Gym	building	Yes
FXSFES2023002599	Miscellaneous finding	Space temperature 69.3 deg. Majority of the areas in the building are being overcooled into the low 70 deg. or even high 60 deg. The temperature is several degrees below the standard of HCPSS Guidelines for Energy Conservation setting of 76 deg. for cooling mode. Building Maintenance to review the HVAC controls and temperature settings to maintain proper temperature and improve energy conservation.	Cafeteria	building	Yes
FXSFES202300259A	Miscellaneous finding	Space temperature 69.9 deg. Majority of the areas in the building are being overcooled into the low 70 deg. or even high 60 deg. The temperature are several degrees below the standard of HCPSS Guidelines for Energy Conservation setting of 76 deg. for cooling mode. Building Maintenance to review the HVAC controls and temperature settings to maintain proper temperature and improve energy conservation.	Health Suite	building	Yes
FXSFES20230025C1	Miscellaneous finding	Thermostat cooling set point set at 74 degrees F. Per the HCPSS Summer Operation Schedule, the set point is to be 82 degrees F.	Portable #109	building	Yes
FXSFES20230025C2	Miscellaneous finding	Thermostat cooling set point set at 74 degrees F. Per the HCPSS Summer Operation Schedule, the set point is to be 82 degrees F.	Portable # 103	building	Yes
FXSFES20230025C3	Miscellaneous finding	Thermostat cooling set point set at 74 degrees F. Per the HCPSS Summer Operation Schedule, the set point is to be 82 degrees F.	Portable # 105	building	Yes
FXSFES20230025C4	Miscellaneous finding	Thermostat cooling set point set at 74 degrees F. Per the HCPSS Summer Operation Schedule, the set point is to be 82 degrees F.	Portable # 170	building	Yes
FXSFES20230025C5	Miscellaneous finding	Thermostat display screen blank.	Portable # 31	building	Yes

Tracking Number	Finding Type	Comments	Location	Assigned To	Closed
FXSFES20230025C6	18" Of Clearance from Ceiling	Miscellaneous items stored less than 18 inches from the ceiling. Remove/reconfigure to allow for 18" of clearance.	Classroom 046	administration	Yes