

Findings for walkthrough River Hill High School: December 11th, 2018

(WXRHHS20180000CF)

Tracking Number	Finding Type	Comments	Location	Assigned To	Closed
FXRHHS20180003BD	Tight seal on ceiling tiles		100	building	Yes
FXRHHS20180003BE	Tight seal on ceiling tiles		100	building	Yes
FXRHHS20180003BF	Tight seal on ceiling tiles		Coo rider behind stage	building	Yes
FXRHHS20180003C0	Tight seal on ceiling tiles		205	building	Yes
FXRHHS20180003C1	Tight seal on ceiling tiles		201	building	Yes
FXRHHS20180003C2	Tight seal on ceiling tiles		214	building	Yes
FXRHHS20180003C3	Tight seal on ceiling tiles		149	building	Yes
FXRHHS20180003C4	Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress		C-200	custodial	Yes
FXRHHS20180003C5	Tight seal on ceiling tiles	Missing ceiling tile	C208	building	Yes
FXRHHS20180003C7	Miscellaneous finding	Storage height	206A	administration	Yes
FXRHHS20180003C8	Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress		S-204b	administration	Yes
FXRHHS20180003CA	Tight seal on ceiling tiles		227	building	Yes
FXRHHS20180003CB	Tight seal on ceiling tiles	Near return	S 228	custodial	Yes
FXRHHS20180003CD	Plumbing fixture leaking/draining slowly	Caulk on toilet and sink	Health Bath	custodial	Yes
FXRHHS20180003CF	Artificial plants/trees		Guidance	administration	Yes
FXRHHS20180003D0	Tight seal on ceiling tiles		Guidance closet	building	Yes
FXRHHS20180003D1	Artificial plants/trees		217	administration	Yes
FXRHHS20180003D2	Artificial plants/trees		217	administration	Yes
FXRHHS20180003D3	Appliances (toaster/coffee maker/fridge/space heaters/air cleaners other than HEPA)		217	administration	Yes

Tracking Number	Finding Type	Comments	Location	Assigned To	Closed
FXRHHS20180003D4	Tight seal on ceiling tiles		226b	building	Yes
FXRHHS20180003D5	Miscellaneous finding	Counter top backsplash delaminated	226b	building	Yes
FXRHHS20180003D7	Tight seal on ceiling tiles		Media	building	Yes
FXRHHS20180003D8	Tight seal on ceiling tiles	Hole Drywall ceiling	Media	building	Yes
FXRHHS20180003DA	Tight seal on ceiling tiles		221	building	Yes
FXRHHS20180003DC	Tight seal on ceiling tiles		Distribution center off of media	building	Yes
FXRHHS20180003DD	Tight seal on ceiling tiles		C 225	building	Yes
FXRHHS20180003DE	Tight seal on ceiling tiles	Hole in tile	Journalism	building	Yes
FXRHHS20180003E0	Tight seal on ceiling tiles		Year ook	building	Yes
FXRHHS20180003E1	Tight seal on ceiling tiles		225A	building	Yes
FXRHHS20180003E2	Odors	Carpet odor	148	environmental	Yes
FXRHHS20180003E3	Tight seal on ceiling tiles		148	building	Yes
FXRHHS20180003E4	Tight seal on ceiling tiles		223	building	Yes
FXRHHS20180003E5	Artificial plants/trees		223	administration	Yes
FXRHHS20180003E6	Tight seal on ceiling tiles	Rusted ceiling grid, place work order for facilities to address and repaint	cafeteria	building	Yes
FXRHHS20180003E8	Tight seal on ceiling tiles	Hole in tile	Conference	building	Yes
FXRHHS20180003EA	Artificial plants/trees		235	administration	Yes
FXRHHS20180003EB	Miscellaneous finding	Items hanging from ceiling	256	administration	Yes
FXRHHS20180003EE	Appliances (toaster/coffee maker/fridge/space heaters/air cleaners other than HEPA)		235	administration	Yes
FXRHHS20180003EF	Appliances (toaster/coffee maker/fridge/space heaters/air cleaners other than HEPA)		238	administration	Yes
FXRHHS20180003F0	Tight seal on ceiling tiles	Stains on 2 tiles	152	building	Yes
FXRHHS20180003F1	Appliances (toaster/coffee maker/fridge/space heaters/air cleaners other than HEPA)		240	administration	Yes

Tracking Number	Finding Type	Comments	Location	Assigned To	Closed
FXRHHS20180003F3	Windows/Doors open		240	building	Yes
FXRHHS20180003F4	Miscellaneous finding	Rust on ventilator	Women's bath next to science	building	Yes
FXRHHS20180003F6	Tight seal on ceiling tiles	Outside of 249	246_hall	building	Yes
FXRHHS20180003F8	Miscellaneous finding	Paint cracked on the wall stairwell	131_hall	building	Yes
FXRHHS20180003FA	General Cleanliness/Dust	Clutter, custodial can't clean	222	administration	Yes
FXRHHS20180003FC	Tight seal on ceiling tiles	One tile in the corner is missing the corner	137	building	Yes
FXRHHS20180003FE	Excessive stuffed animals	Chair	134	administration	Yes
FXRHHS2018000400	Appliances (toaster/coffee maker/fridge/space heaters/air cleaners other than HEPA)	Coffee maker	132	administration	Yes
FXRHHS2018000452	Miscellaneous finding	Rusty floor	Room 102	building	Yes
FXRHHS2018000453	Relative humidity above 70%	far right corner	Boys Locker Room Shower	environmental	Yes
FXRHHS2018000454	General Cleanliness/Dust	Showers dirty	Boys Locker room	custodial	Yes
FXRHHS2018000455	Miscellaneous finding	Floor rusty	Coach's Office	building	Yes
FXRHHS2018000456	Tight seal on ceiling tiles	Gaping around sprinkler head	Weight Room Storage Closet	building	Yes
FXRHHS2018000457	Floor coverings not level or secure (tile, carpets, wood board, etc.)	floor ripped up center near incline bench, floor rusty under water fountain outside Weight Room 117B Vent popped up	Weight Room	building	Yes
FXRHHS2018000458	General Cleanliness/Dust	Vents dirty, one popped up	Room 117	custodial	Yes
FXRHHS2018000459	Tight seal on ceiling tiles		Math Book Room near 117	building	Yes
FXRHHS201800045A	Miscellaneous finding	Boxes of tissues under electrical panels	Electrical Closet near 117	administration	Yes
FXRHHS201800045B	Tight seal on ceiling tiles	Next to TV	Room 122	building	Yes
FXRHHS201800045C	Tight seal on ceiling tiles		Hallway Outside Room 122	administration	Yes
FXRHHS201800045D	Floor coverings not level or secure (tile, carpets, wood board, etc.)	Stained floor tile	C-122	building	Yes
FXRHHS201800045E	Tight seal on ceiling tiles	stains and replacement needed around vent	Staff Lounge B Restrooms	building	Yes

Tracking Number	Finding Type	Comments	Location	Assigned To	Closed
FXRHHS201800045F	Tight seal on ceiling tiles		C-123 Social Studies Book Room	building	Yes
FXRHHS2018000460	Tight seal on ceiling tiles		Room 131	building	Yes
FXRHHS2018000461	Tight seal on ceiling tiles		Book Closet Outside RM 135	building	Yes
FXRHHS2018000462	Tight seal on ceiling tiles		Electrical Room Next to Book Closet RM 135	building	Yes
FXRHHS2018000463	General Cleanliness/Dust	Fridge door molding needs to be cleaned	155B	custodial	Yes
FXRHHS2018000464	Tight seal on ceiling tiles	Wire mesh loose	Room 153	building	Yes
FXRHHS2018000465	Tight seal on ceiling tiles		Wrestling Room	building	Yes
FXRHHS2018000466	Plumbing fixture leaking/draining slowly	Odor	Room 148	building	Yes
FXRHHS2018000467	Tight seal on ceiling tiles	TV pulling tiles	room 148	building	Yes
FXRHHS2018000468	Plumbing fixture leaking/draining slowly	Rusty	Room 146	building	Yes
FXRHHS2018000469	Tight seal on ceiling tiles	Painted	Room 150	building	Yes
FXRHHS201800046A	Tight seal on ceiling tiles		Room 152	building	Yes
FXRHHS201800046B	Tight seal on ceiling tiles		Room 137	building	Yes
FXRHHS201800046C	Appliances (toaster/coffee maker/fridge/space heaters/air cleaners other than HEPA)	Coffee maker	Room 132	administration	Yes
FXRHHS201800046D	Miscellaneous finding	Missing caulk around toilet	Men's Bathroom	building	No