

Findings for walkthrough Swansfield Elementary School: April 10th, 2024

(WXXSES2024000509)

Tracking Number	Finding Type	Comments	Location	Assigned To	Closed
FXXSES2024002830	Appliances (toaster/coffee maker/fridge/space heaters/air cleaners other than HEPA)	A coffee maker and microwave were observed. If not serving an educational purpose, these items are recommended to be removed to improve energy conservation.	210	administration	Yes
FXXSES2024002834	Signs of insects or evidence of pest	Ants or other insects were observed near exterior door.	Cafeteria	building	Yes
FXXSES2024002836	Penetrations not sealed	Evidence of water damaged drywall by door with pests.	Caferia	building	Yes
FXXSES2024002837	Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress	The returns are visibly dirty and require dusting/cleaning.	Kitchen	custodial	Yes
FXXSES2024002839	Excessive stuffed animals	Non-school issued stuffed animals were observed. These items may house allergens if not properly maintained. Remove unnecessary materials or ensure teaching staff has and is following a cleaning schedule (launder or vacuum) since not the responsibility of custodial staff to clean non-school items.	182	administration	Yes
FXXSES202400283B	Obstruction(s) to airflow	The return vent is blocked. It is recommended that the return vent have a minimum of three feet of clearance to facilitate air movement through the space.	180	administration	Yes
FXXSES202400283C	Air freshener/essential oils	Remind staff air fresheners, plug-ins, scent oil sticks, etc. are not permitted because they can mask an odor of concern and/or be an irritant to other individuals.	180	administration	Yes
FXXSES202400283D	Appliances (toaster/coffee maker/fridge/space heaters/air cleaners other than HEPA)	A coffee maker and refrigerator were observed. If not serving an educational purpose, these items are recommended to be removed to improve energy conservation.	178	administration	Yes
FXXSES202400283E	Stained/damaged tiles	Water stained ceiling tiles. If not already being addressed, school custodial staff is to submit a work order to Building Maintenance to evaluate, correct source, and replace ceiling tile.	Outside 167	custodial	Yes
FXXSES2024002840	Appliances (toaster/coffee maker/fridge/space heaters/air cleaners other than HEPA)	A microwave and refrigerator were observed. If not serving an educational purpose, these items are recommended to be removed to improve energy conservation.	150	administration	Yes

Tracking Number	Finding Type	Comments	Location	Assigned To	Closed
FXXSES2024002842	Appliances (toaster/coffee maker/fridge/space heaters/air cleaners other than HEPA)	A microwave and refrigerator were observed. If not serving an educational purpose, these items are recommended to be removed to improve energy conservation.	144	administration	Yes
FXXSES2024002844	Appliances (toaster/coffee maker/fridge/space heaters/air cleaners other than HEPA)	A coffee maker was observed. If not serving an educational purpose, these items are recommended to be removed to improve energy conservation.	1st grade pod	administration	Yes
FXXSES202400284A	Miscellaneous finding	Missing lead signage.	Near 189 and Door 22	building	Yes