

Findings for walkthrough Longfellow Elementary School: April 26th, 2024 (WXLOES202400050C)

Tracking Number	Finding Type	Comments	Location	Assigned To	Closed
FXLOES202400285D	Signs of insects or evidence of pest	Observed ants entering the building through exterior door. If not already being addressed, school custodial staff is to submit a work order to Integrated Pest Management (IPM) to evaluate and address.	310	custodial	Yes
FXLOES202400285E	Stained/damaged tiles	Water stained ceiling tiles. If not already being addressed, school custodial staff is to submit a work order to Building Maintenance to evaluate, correct source, and replace ceiling tile.	Outside 120 cafeteria	custodial	Yes
FXLOES202400285F	Miscellaneous finding	Missing lead signage around faucet.	161	building	No
FXLOES2024002860	Stained/damaged tiles	Water stained ceiling tiles. If not already being addressed, school custodial staff is to submit a work order to Building Maintenance to evaluate, correct source, and replace ceiling tile.	204	custodial	Yes
FXLOES2024002861	Air freshener/essential oils	An aerosol disinfectant spray was observed within the classroom. Such products are not permitted since they can be an airborne irritant when used. Disinfectant wipes and/or the approved cleaning solution from Custodial are permitted.	213	administration	Yes
FXLOES2024002862	Stained/damaged tiles	Water stained ceiling tiles. If not already being addressed, school custodial staff is to submit a work order to Building Maintenance to evaluate, correct source, and replace ceiling tile.	102C	custodial	Yes
FXLOES2024002863	Miscellaneous finding	Lead signage on exterior outlet needs replacement.	Exterior near Cafeteria	building	No
FXLOES2024002864	Miscellaneous finding	Caulking around the building is either detached from sidewalk or damaged and may be pathways for water intrusion. Building maintenance to reapply caulk.	Exterior (Throughout)	building	No