## Findings for walkthrough Folly Quarter Middle School: May 22nd, 2024 (WXFQMS2024000515)

<b>Tracking Number</b>	Finding Type	Comments	Location	<b>Assigned To</b>	Closed
FXFQMS20240028E0	Signs of insects or evidence of pest	Gnats were observed around the window. If not already being addressed, school custodial staff is to submit a work order to Integrated Pest Management to evaluate and correct.	1	custodial	Yes
FXFQMS20240028E1	Appliances (toaster/coffee maker/fridge/space heaters/air cleaners other than HEPA)	A coffee maker was observed. If not serving an educational purpose, these items are recommended to be removed to improve energy conservation.	62	custodial	Yes
FXFQMS20240028E2	Stained/damaged tiles	Water stained ceiling tiles. If not already being addressed, school custodial staff is to submit a work order to Building Maintenance to evaluate, correct source, and replace ceiling tile.	63	custodial	Yes
FXFQMS20240028E3	Appliances (toaster/coffee maker/fridge/space heaters/air cleaners other than HEPA)	A microwave was observed. If not serving an educational purpose, these items are recommended to be removed to improve energy conservation.	6	administration	Yes
FXFQMS20240028E4	Stained/damaged tiles	Water stained ceiling tiles. If not already being addressed, school custodial staff is to submit a work order to Building Maintenance to evaluate, correct source, and replace ceiling tile.	79	custodial	Yes
FXFQMS20240028E5	Appliances (toaster/coffee maker/fridge/space heaters/air cleaners other than HEPA)	A miniature refrigerator was observed. If not serving an educational purpose, these items are recommended to be removed to improve energy conservation.	78	administration	Yes
FXFQMS20240028E6	Miscellaneous finding	Lead signage was missing from science faucets.	73	building	Yes
FXFQMS20240028E7	General Cleanliness/Dust	Dead bugs observed in light fixture and require cleaning.	2nd floor stairwell by room 20	custodial	Yes
FXFQMS20240028E8	Miscellaneous finding	Lead signage was missing from science faucets.	23&27	building	Yes
FXFQMS20240028E9	Appliances (toaster/coffee maker/fridge/space heaters/air cleaners other than HEPA)	A coffee maker was observed. If not serving an educational purpose, these items are recommended to be removed to improve energy conservation.	11	administration	Yes

<b>Tracking Number</b>	Finding Type	Comments	Location	<b>Assigned To</b>	Closed
FXFQMS20240028EA S	tained/damaged tiles	Water stained ceiling tiles. If not already being addressed, school custodial staff is to submit a work order to Building Maintenance to evaluate, correct source, and replace ceiling tile.	102	custodial	Yes
FXFQMS20240028EB C	Obstruction(s) to airflow	The supply diffusers were observed to have covers missing. Covers to be reinstalled.	101	building	Yes