Findings for walkthrough Wilde Lake Middle School: May 29th, 2024 (WXWLMS2024000519)

Tracking Number	Finding Type	Comments	Location	Assigned To	Closed
FXWLMS2024002901	Miscellaneous finding	Missing lead signage.	A28, A32	building	Yes
FXWLMS2024002902	Obstruction(s) to airflow	The return vent was blocked by mats. It is recommended that the return vent have a minimum of three feet of clearance to facilitate air movement through the space.	A34	administration	Yes
FXWLMS2024002903	Appliances (toaster/coffee maker/fridge/space heaters/air cleaners other than HEPA)	An electric kettle was observed. If not serving an educational purpose, these items are recommended to be removed to improve energy conservation.	A77	administration	Yes
FXWLMS2024002904	Miscellaneous finding	Missing lead signage.	A44	building	Yes
FXWLMS2024002905	Appliances (toaster/coffee maker/fridge/space heaters/air cleaners other than HEPA)	An electric kettle was observed. If not serving an educational purpose, these items are recommended to be removed to improve energy conservation.	A44	administration	Yes
FXWLMS2024002906	Appliances (toaster/coffee maker/fridge/space heaters/air cleaners other than HEPA)	A coffee maker was observed. If not serving an educational purpose, these items are recommended to be removed to improve energy conservation.	259	administration	Yes
FXWLMS2024002907	Miscellaneous finding	Missing lead signage.	243	building	Yes
FXWLMS2024002908	Miscellaneous finding	Missing lead signage.	232, 230, 226	building	Yes
FXWLMS2024002909	Miscellaneous finding	Missing lead signage.	Exterior Door 33	building	Yes