

# Findings for walkthrough Laurel Woods Elementary School: October 15th, 2018 (WXLWES20180000D1)

Tracking Number	Finding Type	Comments	Location	Assigned To	Closed
FXLWES2018000405	Visible mold (leak)		Hallway outside of room 155	building	Yes
FXLWES2018000406	Relative humidity above 70%		Hallway outside of room 155	building	Yes