

Findings for walkthrough Ilchester Elementary School: October 28th, 2024 (WXXIES2024000582)

Tracking Number	Finding Type	Comments	Location	Assigned To	Closed
FXXIES2024002C64	Elevated moisture per moisture meter		Room 130	administration	Yes
FXXIES2024002C65	Penetrations not sealed		Room 130	building	Yes