

Findings for walkthrough Wilde Lake Middle School: October 24th, 2024

(WXWLMS2024000588)

Tracking Number	Finding Type	Comments	Location	Assigned To	Closed
FXWLMS2024002C6B	Visible mold on surfaces due to elevated relative humidity/dew point		Cafeteria Stage	administration	Yes
FXWLMS2024002C6C	Relative humidity above 70%		Cafeteria Stage	building	Yes