

# Findings for walkthrough Ducketts Lane Elementary School: July 18th, 2025

## (WXDLES20250005BE)

Tracking Number	Finding Type	Comments	Location	Assigned To	Closed
FXDLES2025002D10	Relative humidity above 70%		Custodial Office	building	Yes