Findings for walkthrough Elkridge Elementary School: July 21st, 2025 (WXXEES20250005C6)

Tracking Number	Finding Type	Comments	Location	Assigned To	Closed
FXXEES2025002D18	Visible mold on surfaces due to elevated relative humidity/dew point		Basement	custodial	Yes