Findings for walkthrough St. John’s Lane Elementary School: February 4th, 2026 (WSJLES2026000609)

Tracking Number	Finding Type	Comments	Location	Assigned To	Closed
FSJLES2026002D59	Bowed ceiling tiles indicating high RH		Rooms 86, 88, & 91	environmental	Yes
FSJLES2026002D5D	General Cleanliness/Dust		Rooms 86, 88, & 91	custodial	Yes