

Findings for walkthrough Howard High School: September 16th, 2026

(WXHOHS202600067B)

Tracking Number	Finding Type	Comments	Location	Assigned To	Closed
FXHOHS2026002DCE	No air flow from diffuser (qualitative)		Health Suite Bathroom	building	No