Findings for walkthrough Clarksville Elementary School: October 27th, 2026 (WXXCES202600069B)

Tracking Number	Finding Type	Comments	Location	Assigned To	Closed
FXXCES2026002DF9	General Cleanliness/Dust		508	custodial	Yes
FXXCES2026002DFA	Signs of insects or evidence of pest		508	building	No
FXXCES2026002DFB	Relative humidity above 70%		508	building	No