

# Findings for walkthrough Wilde Lake Middle School: December 19th, 2018 (WXWLMS20180000E4)

Tracking Number	Finding Type	Comments	Location	Assigned To	Closed
FXWLMS201800051E	Tight seal on ceiling tiles		b18	custodial	Yes
FXWLMS201800051F	Tight seal on ceiling tiles		stair_1	custodial	Yes
FXWLMS2018000520	General Cleanliness/Dust	Dusty	203	custodial	Yes
FXWLMS2018000521	General Cleanliness/Dust	Top of file cabinet	203	custodial	Yes
FXWLMS2018000522	Tight seal on ceiling tiles		b20	custodial	Yes
FXWLMS2018000523	Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress	Local exhaust	205	administration	Yes
FXWLMS2018000524	General Cleanliness/Dust	Dust top of lockers	217_hall	custodial	Yes
FXWLMS2018000525	Tight seal on ceiling tiles	Ceiling vent for air duct has brown spots. Maybe condensation	a57	custodial	Yes
FXWLMS2018000527	Floor coverings not level or secure (tile, carpets, wood board, etc.)		b29	building	No
FXWLMS2018000528	General Cleanliness/Dust	Construction dust heavy on shelving	214	custodial	Yes
FXWLMS2018000529	Miscellaneous finding	Condensation or old minor leak showing on pipes?	a59		No
FXWLMS201800052B	Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress	Return air	217	administration	Yes
FXWLMS201800052C	Tight seal on ceiling tiles	Stain along hall wall	217	custodial	Yes
FXWLMS201800052D	General Cleanliness/Dust	Shelf near teacher desk	208	custodial	Yes
FXWLMS201800052F	Tight seal on ceiling tiles	Dust on vent	a40	custodial	Yes
FXWLMS2018000530	Tight seal on ceiling tiles		a70	custodial	Yes
FXWLMS2018000531	Tight seal on ceiling tiles	Leak on tile	a70	custodial	Yes
FXWLMS2018000532	General Cleanliness/Dust	File cabinet	stair_2	custodial	Yes
FXWLMS2018000533	Tight seal on ceiling tiles	Ceiling tile leak by flag	a43	custodial	Yes

<b>Tracking Number</b>	<b>Finding Type</b>	<b>Comments</b>	<b>Location</b>	<b>Assigned To</b>	<b>Closed</b>
FXWLMS2018000534	General Cleanliness/Dust	File cabinet	224	custodial	Yes
FXWLMS2018000536	Tight seal on ceiling tiles	Use ceiling tile clips	a43	custodial	Yes
FXWLMS201800053A	Tight seal on ceiling tiles	Skylight leaking in 3 locations. One in middle left side walking in. One when you walk in. And one on right side when you walk in.	a49	custodial	Yes
FXWLMS201800053B	Elevated moisture per moisture meter	Signs of past water staining	230	environmental	Yes
FXWLMS201800053C	Floor coverings not level or secure (tile, carpets, wood board, etc.)	Floor tile popping up near slop sink	241	building	No
FXWLMS201800053D	Miscellaneous finding	Items floor	256		No
FXWLMS201800053E	Miscellaneous finding	Items floor	256		No
FXWLMS201800053F	General Cleanliness/Dust	Dusty surfaces	246	custodial	Yes
FXWLMS2018000540	Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress	Local. Exhaust and return air	249	administration	Yes
FXWLMS2018000541	Electrical wiring exposed or disconnected wires	Light does not turn on	250	administration	Yes
FXWLMS2018000542	Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress		251	administration	Yes
FXWLMS2018000543	General Cleanliness/Dust		Hallway	custodial	Yes
FXWLMS2018000544	General Cleanliness/Dust		247_hall	custodial	Yes
FXWLMS2018000545	General Cleanliness/Dust		230_hall	custodial	Yes