

# Findings for walkthrough Centennial High School: October 29th, 2019

## (WXXCHS20190000F2)

Tracking Number	Finding Type	Comments	Location	Assigned To	Closed
FXXCHS20190005D6	Visible mold on surfaces due to elevated relative humidity/dew point		Portable 4	building	Yes