

Findings for walkthrough Bollman Bridge Elementary School: September 5th, 2018 (WXBBES2018000016)

Tracking Number	Finding Type	Comments	Location	Assigned To	Closed
FXBBES2018000013	Visible mold on surfaces due to elevated relative humidity/dew point		PE Office	environmental	Yes
FXBBES2018000014	Miscellaneous finding		PE Office	administration	Yes