

Findings for walkthrough Elkridge Landing Middle School: January 10th, 2019

(WXELMS20190000FC)

Tracking Number	Finding Type	Comments	Location	Assigned To	Closed
FXELMS201900068C	Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress	Vent dirty	Closet	administration	Yes
FXELMS201900068D	Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress	Return dirty	Office	administration	Yes
FXELMS201900068E	Tight seal on ceiling tiles	Stained tile	Science closet	custodial	Yes
FXELMS201900068F	Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress	Dirty vent and wall near it	Science closet	administration	Yes
FXELMS2019000690	Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress	Dirty	117a	administration	Yes
FXELMS2019000691	Floor coverings not level or secure (tile, carpets, wood board, etc.)	Rip	115	building	No
FXELMS2019000692	Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress		114	administration	Yes
FXELMS2019000693	General Cleanliness/Dust	Dust on some surfaces	114	custodial	Yes
FXELMS2019000694	Floor coverings not level or secure (tile, carpets, wood board, etc.)	Ripped	114	building	No
FXELMS2019000695	Exterior doors not fully sealed (daylight)		113	building	No
FXELMS2019000696	Signs of insects or evidence of pest	Ant trap at sink	Seminar	building	No
FXELMS2019000697	Uncomfortable temperature		Prep	building	No
FXELMS2019000698	Signs of insects or evidence of pest	Mouse trap	Prep	building	No
FXELMS2019000699	Exterior doors not fully sealed (daylight)	Starting to rust at bottom	112	building	No
FXELMS201900069A	Blocked temperature sensors	File bin against stat	111	administration	Yes
FXELMS201900069B	General Cleanliness/Dust	Dusty surfaces	110	custodial	Yes
FXELMS201900069C	Uncomfortable temperature	Warmer then others	108	building	No

Tracking Number	Finding Type	Comments	Location	Assigned To	Closed
FXELMS201900069D	Tight seal on ceiling tiles	About 4 ceiling tiles to right of elevator - 2x4 tile near light lense - 2" diameter stain	Hall	custodial	Yes
FXELMS201900069E	Tight seal on ceiling tiles	Stain	106	custodial	Yes
FXELMS201900069F	Exterior doors not fully sealed (daylight)	Bottom of exit door	106	building	No
FXELMS20190006A0	Tight seal on ceiling tiles	Blistering paint on drywall ceiling	Boys restroom	custodial	Yes
FXELMS20190006A1	Tight seal on ceiling tiles	Stained tile corner tile touching boys restroom wall	Hall	custodial	Yes
FXELMS20190006A2	Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress	Dirty	104	administration	Yes
FXELMS20190006A3	General Cleanliness/Dust	Food in plastic bags that mice can get at	102	administration	Yes
FXELMS20190006A4	Miscellaneous finding	Right window gap in Cmu wall to right of window lower wall expansion joint	102		No
FXELMS20190006A5	Tight seal on ceiling tiles	Ceiling tile above entrance neede to be replaced.	204	custodial	Yes
FXELMS20190006A6	Floor coverings not level or secure (tile, carpets, wood board, etc.)	Carpet near entrance is ripped	204	building	No
FXELMS20190006A7	Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress	Backside of return	141	administration	Yes
FXELMS20190006A8	Tight seal on ceiling tiles	Stain around insulated pipe	144	custodial	Yes
FXELMS20190006A9	Tight seal on ceiling tiles	Missing	Storage	custodial	Yes
FXELMS20190006AA	General Cleanliness/Dust	Items to be sold in wrappers but accessible to mice	School store	administration	Yes
FXELMS20190006AB	Tight seal on ceiling tiles	Stained	School store	custodial	Yes
FXELMS20190006AC	Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress	Dirty	119	administration	Yes
FXELMS20190006AD	Tight seal on ceiling tiles	Minor stain near exit door	119	custodial	Yes
FXELMS20190006AE	Tight seal on ceiling tiles	Stains	Pantry	custodial	Yes
FXELMS20190006AF	Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress	Dirty	Media	administration	Yes
FXELMS20190006B1	Uncomfortable temperature	Too warm	148	building	No