

Findings for walkthrough Clemens Crossing Elementary School: January 23rd, 2019 (WXCCES201900010D)

Tracking Number	Finding Type	Comments	Location	Assigned To	Closed
FXCCES2019000757	Excessive stuffed animals		197	administration	Yes
FXCCES2019000759	Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress	Vent rusty - submit work order for Building Services to replace or repaint.	Kitchen Dishwashing Area	administration	Yes
FXCCES201900075B	Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress	Rusty supply diffuser	136	administration	Yes
FXCCES201900075D	Tight seal on ceiling tiles	Stained tile in gym office	146	custodial	Yes
FXCCES201900075F	Appliances (toaster/coffee maker/fridge/space heaters/air cleaners other than HEPA)	Health Office	Health	administration	Yes
FXCCES2019000761	Excessive stuffed animals		194	administration	Yes
FXCCES2019000762	Tight seal on ceiling tiles		193	custodial	Yes
FXCCES2019000763	Uncomfortable temperature		193	building	No
FXCCES2019000764	Excessive stuffed animals		192	administration	Yes
FXCCES2019000765	Tight seal on ceiling tiles		3rd Grade Boys Bath	custodial	Yes
FXCCES2019000766	Excessive stuffed animals	Stuffed animals need a plan for occasional cleaning	150	administration	Yes
FXCCES2019000768	Tight seal on ceiling tiles		182	custodial	Yes
FXCCES2019000769	Tight seal on ceiling tiles		183	custodial	Yes
FXCCES201900076A	Tight seal on ceiling tiles		184	custodial	Yes
FXCCES201900076B	Excessive stuffed animals	Stuffed animals need plan for occasional cleaning	184	administration	Yes
FXCCES201900076D	Tight seal on ceiling tiles		185	custodial	Yes
FXCCES201900076E	Appliances (toaster/coffee maker/fridge/space heaters/air cleaners other than HEPA)	Refrigerator	133	administration	Yes
FXCCES2019000770	Tight seal on ceiling tiles		Team 4 area	custodial	Yes