

# Findings for walkthrough Guilford Elementary School: December 15th, 2018 (WXXGES2018000026)

| Tracking Number  | Finding Type                | Comments | Location                   | Assigned To | Closed |
|------------------|-----------------------------|----------|----------------------------|-------------|--------|
| FXXGES201800000A | Relative humidity above 70% |          | Gymnasium Storage building |             | Yes    |