

Findings for walkthrough Manor Woods Elementary School: February 7th, 2019 (WXMWES2019000127)

Tracking Number	Finding Type	Comments	Location	Assigned To	Closed
FXMWES2019000907	Signs of insects or evidence of pest		Cafeteria	building	No
FXMWES2019000908	Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress	Dirty supply and return	Office	administration	Yes
FXMWES2019000909	Signs of insects or evidence of pest	Dead bugs behind light covers	Office	building	No
FXMWES201900090C	Signs of insects or evidence of pest	Dead bugs behind light lense	162	building	No
FXMWES201900090D	Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress	Supply dirty	162	custodial	Yes
FXMWES201900090E	Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress		Main office	administration	Yes
FXMWES2019000911	Exterior doors not fully sealed (daylight)		Gym_156	building	No
FXMWES2019000912	Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress		Health_Suite_104	administration	Yes
FXMWES2019000915	General Cleanliness/Dust		152	custodial	Yes
FXMWES2019000917	Excessive stuffed animals	Curtains	c05	administration	Yes
FXMWES2019000918	Excessive stuffed animals	Tablecloths	c06	administration	Yes
FXMWES2019000919	General Cleanliness/Dust	Fish food out	Hallway	administration	Yes
FXMWES201900091A	Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress		113	custodial	Yes
FXMWES201900091B	General Cleanliness/Dust		c07	administration	Yes
FXMWES201900091C	Excessive stuffed animals		c07	administration	Yes
FXMWES201900091D	Excessive stuffed animals		c09	administration	Yes
FXMWES201900091E	Appliances (toaster/coffee maker/fridge/space heaters/air cleaners other than HEPA)		c09	administration	Yes

Tracking Number	Finding Type	Comments	Location	Assigned To	Closed
FXMWES201900091F	Artificial plants/trees		c09	administration	Yes
FXMWES2019000920	Miscellaneous finding	Dust and gross around the pipe in the supply closet	108		No
FXMWES2019000922	Elevated moisture per moisture meter		151	custodial	Yes
FXMWES2019000923	General Cleanliness/Dust		c09	administration	Yes
FXMWES2019000924	Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress		114	administration	Yes
FXMWES2019000925	General Cleanliness/Dust		c10	administration	Yes
FXMWES2019000926	Appliances (toaster/coffee maker/fridge/space heaters/air cleaners other than HEPA)		c10	administration	Yes
FXMWES2019000927	General Cleanliness/Dust	Cobwebs on ceiling panel cover	Girls toilet	custodial	Yes
FXMWES2019000928	Elevated moisture per moisture meter	Stained tiles around and under soap dispenser	Boys toilet	custodial	Yes
FXMWES2019000929	Plumbing fixture leaking/draining slowly		150	custodial	Yes
FXMWES201900092A	Exterior doors not fully sealed (daylight)		150	building	No
FXMWES201900092B	Air freshener/essential oils		Staff restroom	administration	Yes
FXMWES201900092C	Excessive stuffed animals		B08	administration	Yes
FXMWES201900092D	Miscellaneous finding		B08	administration	Yes
FXMWES201900092E	Miscellaneous finding	Soap dispenser missing cover	Girls bathroom	administration	Yes
FXMWES201900092F	General Cleanliness/Dust		B08	custodial	Yes
FXMWES2019000930	Excessive stuffed animals		126	administration	Yes
FXMWES2019000931	Excessive stuffed animals		127	administration	Yes
FXMWES2019000932	Excessive stuffed animals		128	administration	Yes
FXMWES2019000933	Tight seal on ceiling tiles		167	custodial	Yes
FXMWES2019000934	Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress	Dirty supply	166	custodial	Yes
FXMWES2019000935	Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress	Dirty supply	166	custodial	Yes
FXMWES2019000936	Excessive stuffed animals		129	administration	Yes

Tracking Number	Finding Type	Comments	Location	Assigned To	Closed
FXMWES2019000937	Miscellaneous finding	Corner shared by 173 and 170 burrow under cement pad water can go and may impact walls or slab	173	building	No
FXMWES2019000938	Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress	Supply vents dirty	176	custodial	Yes
FXMWES2019000939	Miscellaneous finding	Missing soap dispenser	132	administration	Yes
FXMWES201900093A	Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress	Supply vent dirty	178	custodial	Yes
FXMWES201900093B	General Cleanliness/Dust	Some bugs in light	132	custodial	Yes
FXMWES201900093C	General Cleanliness/Dust		147	custodial	Yes
FXMWES201900093D	Excessive stuffed animals		131	administration	Yes
FXMWES201900093E	Tight seal on ceiling tiles	Hole in tile around pipes	183	custodial	Yes
FXMWES201900093F	Signs of insects or evidence of pest	Bugs in light	Vestibule	building	No
FXMWES2019000940	Excessive stuffed animals	Stuffed animals, flags (teacher notes they were sprayed)	137	administration	Yes
FXMWES2019000941	Excessive stuffed animals		136	administration	Yes
FXMWES2019000942	Tight seal on ceiling tiles		145	custodial	Yes
FXMWES2019000943	Excessive stuffed animals		134	administration	Yes
FXMWES2019000944	Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress	Supply diffuser dirty	142	custodial	Yes
FXMWES2019000945	Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress	Supply vents dirty	139	custodial	Yes
FXMWES2019000946	Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress	Supply vents dirty	144	custodial	Yes
FXMWES2019000947	Miscellaneous finding	Large crack in block wall left of chalkboard	144		No
FXMWES2019000948	Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress	Supply vents dirty	140	custodial	Yes