

Findings for walkthrough Elkridge Elementary School: September 4th, 2018 (WXXEES2018000044)

Tracking Number	Finding Type	Comments	Location	Assigned To	Closed
FXXEES201800003D	Relative humidity above 70%		Basement Level	building	Yes