

# Findings for walkthrough Mount View Middle School: October 11th, 2018 (WXMVMS2018000048)

Tracking Number	Finding Type	Comments	Location	Assigned To	Closed
FXMVMS201800003E	Visible mold on surfaces due to elevated relative humidity/dew point		Room 15	building	Yes