

Findings for walkthrough Patuxent Valley Middle School: October 15th, 2018 (WXPVMS201800004F)

Tracking Number	Finding Type	Comments	Location	Assigned To	Closed
FXPVMS2018000045	Tight seal on ceiling tiles	Stained ceiling tile.	102	custodial	Yes
FXPVMS201800004A	Tight seal on ceiling tiles	Back wall/ ceiling	104	custodial	Yes
FXPVMS201800004B	Miscellaneous finding	Missing escutcheon plate	Bathroom next to Custodial Office	building	No
FXPVMS201800004E	Tight seal on ceiling tiles		Smith-Green Office	custodial	Yes
FXPVMS201800004F	Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress	Bookcase blocking air return vent	116	administration	Yes
FXPVMS2018000050	Miscellaneous finding	Water in light	Smith-Green Office	building	No
FXPVMS2018000052	Elevated moisture per moisture meter	Missing clamp, leak below	Media	environmental	Yes
FXPVMS2018000055	Tight seal on ceiling tiles	Ceiling tile	Storage D107	custodial	Yes
FXPVMS2018000056	Floor coverings not level or secure (tile, carpets, wood board, etc.)	Behind door	Storage D107	building	No
FXPVMS2018000057	General Cleanliness/Dust	Ducks on top of bookcase	109	custodial	Yes
FXPVMS2018000059	Tight seal on ceiling tiles	Ceiling down	Elevator Room	custodial	Yes
FXPVMS201800005B	Floor coverings not level or secure (tile, carpets, wood board, etc.)		136	building	No
FXPVMS201800005C	Tight seal on ceiling tiles	Minor ceiling tile stains. Custodial to assess and place work order. as needed.	Counseling conf room	custodial	Yes
FXPVMS201800005D	Tight seal on ceiling tiles	Water stain above shelving (near valve 135)	111	custodial	Yes
FXPVMS2018000060	Tight seal on ceiling tiles	Water stain above white board (right side) back of room	111	custodial	Yes
FXPVMS2018000062	Tight seal on ceiling tiles	Water stain on 2 ceiling tiles near flag	111	custodial	Yes
FXPVMS2018000064	Tight seal on ceiling tiles		A116 Storage	custodial	Yes

Tracking Number	Finding Type	Comments	Location	Assigned To	Closed
FXPVMS2018000067	Tight seal on ceiling tiles	Flaking peeling paint.	Storage off of tech ed	custodial	Yes
FXPVMS2018000069	Tight seal on ceiling tiles	Water stain on ceiling in front of room 112	119_hall	custodial	Yes
FXPVMS201800006B	Artificial plants/trees		205	administration	Yes
FXPVMS201800006C	Exterior doors not fully sealed (daylight)	Window gap above girls bath on 2nd floor main hall.	203	building	No
FXPVMS201800006E	Tight seal on ceiling tiles		FACS	custodial	Yes
FXPVMS201800006F	Tight seal on ceiling tiles	Water damage to ceiling tile, left side classroom	112	custodial	Yes
FXPVMS2018000070	Tight seal on ceiling tiles		Boys Restroom	custodial	Yes
FXPVMS2018000072	Exterior doors not fully sealed (daylight)	Small gap to exterior door	112	building	No
FXPVMS2018000074	Tight seal on ceiling tiles	Pantoulis office	198	custodial	Yes
FXPVMS2018000075	Tight seal on ceiling tiles		198	custodial	Yes
FXPVMS2018000079	Odors		146	environmental	Yes
FXPVMS201800007A	Tight seal on ceiling tiles	Water stain in entry to classroom	102	custodial	Yes
FXPVMS201800007C	Floor coverings not level or secure (tile, carpets, wood board, etc.)	Stains (?) on tiles	102	building	No
FXPVMS201800007E	General Cleanliness/Dust		Electrical Room C2	custodial	Yes
FXPVMS201800007F	Tight seal on ceiling tiles		Principal Bath	custodial	Yes
FXPVMS2018000080	Tight seal on ceiling tiles		B103	custodial	Yes
FXPVMS2018000081	Floor coverings not level or secure (tile, carpets, wood board, etc.)	Marks on floor	119	building	No
FXPVMS2018000083	General Cleanliness/Dust		Pra Storage	custodial	Yes
FXPVMS2018000084	Tight seal on ceiling tiles	Water in lense	122	custodial	Yes
FXPVMS2018000086	Tight seal on ceiling tiles		122	custodial	Yes
FXPVMS2018000087	Tight seal on ceiling tiles		126	custodial	Yes
FXPVMS2018000088	Tight seal on ceiling tiles	Caulking needed	124	custodial	Yes
FXPVMS2018000089	Tight seal on ceiling tiles		128	custodial	Yes