

Findings for walkthrough Thunder Hill Elementary School: March 18th, 2019 (WXTHES201900017D)

Tracking Number	Finding Type	Comments	Location	Assigned To	Closed
FXTHES2019000CD8	General Cleanliness/Dust	Dead bugs in lights	305	custodial	Yes
FXTHES2019000CD9	Floor coverings not level or secure (tile, carpets, wood board, etc.)	Dust in corners near cubbies	131	custodial	Yes
FXTHES2019000CDC	Excessive stuffed animals		305	administration	Yes
FXTHES2019000CDD	General Cleanliness/Dust		130	custodial	Yes
FXTHES2019000CDE	General Cleanliness/Dust	Dead bugs in lights	Stage Ramp	custodial	Yes
FXTHES2019000CE0	Appliances (toaster/coffee maker/fridge/space heaters/air cleaners other than HEPA)	Personal lamps and appliances	129	administration	Yes
FXTHES2019000CE1	Tight seal on ceiling tiles	Hole in ceiling.	Kitchen - Dishwashing	custodial	Yes
FXTHES2019000CE4	Miscellaneous finding	At slop sink area pipe insulation deteriorating.	A33	building	No
FXTHES2019000CE6	Electrical equipment near sinks or source of water		126	administration	Yes
FXTHES2019000CE7	General Cleanliness/Dust	Freezer door should be cleaned occasionally by kitchen staff.	Kitchen Freezer	administration	Yes
FXTHES2019000CE9	General Cleanliness/Dust	Mechanical Room Behind Custodial Office - Vent above water heater needs to be cleaned	A33	custodial	Yes
FXTHES2019000CEA	General Cleanliness/Dust		123	custodial	Yes
FXTHES2019000CEC	General Cleanliness/Dust		121	custodial	Yes
FXTHES2019000CED	Tight seal on ceiling tiles	Dirt on ceilings near supply diffusers	101	custodial	Yes
FXTHES2019000CEF	General Cleanliness/Dust	Dead bugs in lights (bathroom)	101	custodial	Yes
FXTHES2019000CF2	General Cleanliness/Dust		118	custodial	Yes
FXTHES2019000CF3	Artificial plants/trees		118	administration	Yes
FXTHES2019000CF4	Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress		Gym Storage	administration	Yes

Tracking Number	Finding Type	Comments	Location	Assigned To	Closed
FXTHES2019000CF5	General Cleanliness/Dust	Dead bugs in lights	Cust closet across frOn 100	custodial	Yes
FXTHES2019000CF7	Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress	Vent on wall dirty and coming off	Girls Bath across from 100	building	No
FXTHES2019000CF9	General Cleanliness/Dust		115	custodial	Yes
FXTHES2019000CFA	Electrical equipment near sinks or source of water		114	administration	Yes
FXTHES2019000CFB	General Cleanliness/Dust	Dust on floors and corners	114	custodial	Yes
FXTHES2019000CFC	Miscellaneous finding	Clutterness near front board	113	administration	Yes
FXTHES2019000CFD	General Cleanliness/Dust		113	custodial	Yes
FXTHES2019000CFE	Miscellaneous finding	Clutter near teacher desk area	120	administration	Yes
FXTHES2019000CFF	Miscellaneous finding	Percentage of wall covered with papers/posters	112	administration	Yes
FXTHES2019000D00	Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress	Supply diffusers dirty	Media	custodial	Yes
FXTHES2019000D02	General Cleanliness/Dust		111	custodial	Yes
FXTHES2019000D03	Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress		Telecom across from 126	custodial	Yes
FXTHES2019000D04	Tight seal on ceiling tiles		Office across from 205	custodial	Yes
FXTHES2019000D05	Tight seal on ceiling tiles		212	custodial	Yes
FXTHES2019000D06	General Cleanliness/Dust	Dead bugs in lights	Custodial Closet across from c05	custodial	Yes
FXTHES2019000D08	Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress		C05 Elec Room	custodial	Yes
FXTHES2019000D09	General Cleanliness/Dust	Dead bugs in lights	Cust across from c18	custodial	Yes