

Findings for walkthrough Glenelg High School: April 3rd, 2019 (WXXGHS2019000195)

Tracking Number	Finding Type	Comments	Location	Assigned To	Closed
FXXGHS2019000E8B	Appliances (toaster/coffee maker/fridge/space heaters/air cleaners other than HEPA)	Toaster oven	113	administration	Yes
FXXGHS2019000E8D	General Cleanliness/Dust	Floor dirty	Sprinkler room	custodial	Yes
FXXGHS2019000E8F	Artificial plants/trees		Front Office	administration	Yes
FXXGHS2019000E90	Electrical cords unsecured, extend across walkways, cord protectors not installed	cord is tripping hazard by teacher desk	161	administration	Yes
FXXGHS2019000E91	Electrical cords unsecured, extend across walkways, cord protectors not installed		160	administration	Yes
FXXGHS2019000E93	Electrical cords unsecured, extend across walkways, cord protectors not installed		156	administration	Yes
FXXGHS2019000E94	Tight seal on ceiling tiles		213	custodial	Yes
FXXGHS2019000E95	Tight seal on ceiling tiles		213	custodial	Yes
FXXGHS2019000E96	Tight seal on ceiling tiles		218	custodial	Yes
FXXGHS2019000E97	Tight seal on ceiling tiles		Storage	custodial	Yes
FXXGHS2019000E98	Miscellaneous finding	best door lock needs rTo be changed	147		No
FXXGHS2019000E9B	Excessive stuffed animals	Stuffed animals	147	administration	Yes
FXXGHS2019000E9C	Electrical cords unsecured, extend across walkways, cord protectors not installed		146	administration	Yes
FXXGHS2019000E9E	Miscellaneous finding	broken light by teachers desk	145	custodial	Yes
FXXGHS2019000EA0	Appliances (toaster/coffee maker/fridge/space heaters/air cleaners other than HEPA)	Toaster oven	143	administration	Yes
FXXGHS2019000EA2	Electrical cords unsecured, extend across walkways, cord protectors not installed	extension cord to LCD projector needs to be covered tripping hazard	141	administration	Yes
FXXGHS2019000EA4	Electrical cords unsecured, extend across walkways, cord protectors not installed	Extension cord from led card is uncovered and a tripping hazard	139	administration	Yes

Tracking Number	Finding Type	Comments	Location	Assigned To	Closed
FXXGHS2019000EA5	Tight seal on ceiling tiles		136	custodial	Yes
FXXGHS2019000EA7	Miscellaneous finding	Broken bulletin board	136	building	No
FXXGHS2019000EA9	Miscellaneous finding	No Emergency lights	137	building	No
FXXGHS2019000EAB	Signs of insects or evidence of pest	ants coming through crack by window	137	building	No
FXXGHS2019000EAD	Miscellaneous finding	Screens missing from two windows	137	building	No
FXXGHS2019000EAE	Artificial plants/trees		Media office	administration	Yes
FXXGHS2019000EB0	Artificial plants/trees		124	administration	Yes
FXXGHS2019000EB1	Artificial plants/trees		Psychologist office	administration	Yes
FXXGHS2019000EB2	General Cleanliness/Dust	Gum on Seats in row 3	auditorium	custodial	Yes
FXXGHS2019000EB4	Miscellaneous finding	door handle leading to stage is broken	305	building	No
FXXGHS2019000EB6	Tight seal on ceiling tiles	Cracked ceiling tile near pa	304a	custodial	Yes
FXXGHS2019000EB8	Uncomfortable temperature	Too hot	304a	building	No
FXXGHS2019000EBA	Tight seal on ceiling tiles	Near Paris speaker	304b	custodial	Yes
FXXGHS2019000EBC	Uncomfortable temperature		302	building	No
FXXGHS2019000EBD	Miscellaneous finding	Broken step, moldings	302	building	No
FXXGHS2019000EBF	Miscellaneous finding	Door striker needs to be replaced	instrument Storage Room	building	No
FXXGHS2019000EC2	Floor coverings not level or secure (tile, carpets, wood board, etc.)		176	building	No
FXXGHS2019000EC3	Miscellaneous finding	lock on restroom needs to be changed to allow master key	Men's Room	building	No
FXXGHS2019000EC5	Uncomfortable temperature	Too cold	312	building	No
FXXGHS2019000EC7	Uncomfortable temperature		312	building	No
FXXGHS2019000ECA	Tight seal on ceiling tiles		Psychologist Office	administration	Yes
FXXGHS2019000ECB	Plumbing fixture leaking/draining slowly	Per the teacher, during the air conditioning mode condensation water comes of the wall AC unit and the carpet gets wet.	Room 175	building	No
FXXGHS2019000ECC	Miscellaneous finding	Per the teacher, water comes in thru the abandoned dust collector.	Room 176	building	No

Tracking Number	Finding Type	Comments	Location	Assigned To	Closed
FXXGHS2019000ECD	Miscellaneous finding	Paint peeling off the wall and the ductwork	Storage Room off of room 176	building	No
FXXGHS2019000ECE	Miscellaneous finding	Loud airflow noise from the heating/AC system.	Storage Room off of room 116	building	No