

Findings for walkthrough Elkridge Elementary School: April 10th, 2019

(WXXEES201900019F)

| Tracking Number | Finding Type | Comments | Location | Assigned To | Closed |
|------------------|--|---------------------------------|---------------|----------------|--------|
| FXXEES2019000F7B | Miscellaneous finding | Crack in CMU | Entry Hall | building | No |
| FXXEES2019000F7F | Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress | | 033 | custodial | Yes |
| FXXEES2019000F80 | Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress | | 036 | custodial | Yes |
| FXXEES2019000F81 | Tight seal on ceiling tiles | | 111 | custodial | Yes |
| FXXEES2019000F82 | Artificial plants/trees | | 111 | administration | Yes |
| FXXEES2019000F83 | Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress | | 035 | custodial | Yes |
| FXXEES2019000F84 | Tight seal on ceiling tiles | | 035 | custodial | Yes |
| FXXEES2019000F85 | Tight seal on ceiling tiles | | 109 | custodial | Yes |
| FXXEES2019000F86 | Tight seal on ceiling tiles | | Open pod area | custodial | Yes |
| FXXEES2019000F87 | Plumbing fixture leaking/draining slowly | | 034 | building | Yes |
| FXXEES2019000F88 | Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress | | 034 | custodial | Yes |
| FXXEES2019000F89 | General Cleanliness/Dust | | 034 | custodial | Yes |
| FXXEES2019000F8A | General Cleanliness/Dust | | 034 | custodial | Yes |
| FXXEES2019000F8B | General Cleanliness/Dust | | 034 | custodial | Yes |
| FXXEES2019000F8C | General Cleanliness/Dust | | 032 | custodial | Yes |
| FXXEES2019000F8D | Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress | | 032 | custodial | Yes |
| FXXEES2019000F8E | Windows/Doors open | 2 Windows open | 74 | administration | Yes |
| FXXEES2019000F90 | Tight seal on ceiling tiles | Tile above teacher desk stained | 74 | custodial | Yes |

| Tracking Number | Finding Type | Comments | Location | Assigned To | Closed |
|------------------|--|---------------------------------------|-------------------------------|----------------|--------|
| FXXEES2019000F91 | Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress | Supply diffusers dirty | 016 | custodial | Yes |
| FXXEES2019000F93 | Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress | | Lou ge | custodial | Yes |
| FXXEES2019000F95 | Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress | | Closet | custodial | Yes |
| FXXEES2019000F97 | Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress | | 028 | custodial | Yes |
| FXXEES2019000F98 | Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress | | Closet 4th | custodial | Yes |
| FXXEES2019000F99 | Tight seal on ceiling tiles | Ceiling tile in closet stained | 73 | custodial | Yes |
| FXXEES2019000F9A | Miscellaneous finding | Return and pipe insulation very dusty | PE Storage | custodial | Yes |
| FXXEES2019000F9B | Plumbing fixture leaking/draining slowly | Faucet dripping | 72 | building | Yes |
| FXXEES2019000F9E | General Cleanliness/Dust | Housekeeping poor | Pe storage closest to offices | custodial | Yes |
| FXXEES2019000FA0 | Appliances (toaster/coffee maker/fridge/space heaters/air cleaners other than HEPA) | Microwave | Pe office 2 | administration | Yes |
| FXXEES2019000FA2 | Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress | Supply diffusers dirty | 017 | custodial | Yes |
| FXXEES2019000FA3 | Plumbing fixture leaking/draining slowly | | 017 | building | Yes |
| FXXEES2019000FA4 | Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress | | 016 | custodial | Yes |
| FXXEES2019000FA5 | Tight seal on ceiling tiles | | 013 | custodial | Yes |
| FXXEES2019000FA6 | General Cleanliness/Dust | | 014 | custodial | Yes |
| FXXEES2019000FA7 | Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress | Supply diffusers dirty | South America Hallway | custodial | Yes |
| FXXEES2019000FA9 | Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress | Returns Dirty | 5th Grade Storage | custodial | Yes |
| FXXEES2019000FAA | Uncomfortable temperature | | 006 | building | Yes |

| Tracking Number | Finding Type | Comments | Location | Assigned To | Closed |
|------------------|--|---------------------------------|---------------------|----------------|--------|
| FXXEES2019000FAD | Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress | | 003-2 | custodial | Yes |
| FXXEES2019000FAE | Odors | | 003-2 | administration | Yes |
| FXXEES2019000FAF | Plumbing fixture leaking/draining slowly | | 003-2 | building | Yes |
| FXXEES2019000FB0 | Electrical cords unsecured, extend across walkways, cord protectors not installed | | 001 | administration | Yes |
| FXXEES2019000FB3 | Tight seal on ceiling tiles | | 003 | custodial | Yes |
| FXXEES2019000FB4 | Miscellaneous finding | Water stained light | 85 | administration | Yes |
| FXXEES2019000FB6 | Artificial plants/trees | | 92 | administration | Yes |
| FXXEES2019000FB7 | Tight seal on ceiling tiles | | 5th Grade Staiewell | custodial | Yes |
| FXXEES2019000FB8 | Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress | | 019 | custodial | Yes |
| FXXEES2019000FB9 | Tight seal on ceiling tiles | | Janitor closet | custodial | Yes |
| FXXEES2019000FBA | Tight seal on ceiling tiles | | 009 | custodial | Yes |
| FXXEES2019000FBB | Plumbing fixture leaking/draining slowly | | 010 | building | Yes |
| FXXEES2019000FBC | Tight seal on ceiling tiles | | Hallway | custodial | Yes |
| FXXEES2019000FBD | Miscellaneous finding | | Potable 159 | building | Yes |
| FXXEES2019000FBF | Air freshener/essential oils | | Staff Bath | administration | Yes |
| FXXEES2019000FC0 | Miscellaneous finding | | Staff Bath | administration | Yes |
| FXXEES2019000FC1 | Miscellaneous finding | Rust on wall panel | 1st Grade Boys Bath | building | Yes |
| FXXEES2019000FC3 | Miscellaneous finding | Exterior damage around portable | Portable 159 | building | Yes |