

Findings for walkthrough Guilford Elementary School: April 23rd, 2019 (WXXGES20190001A1)

Tracking Number	Finding Type	Comments	Location	Assigned To	Closed
FXXGES2019000FC7	Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress	Return dusty	gym	custodial	Yes
FXXGES2019000FC9	Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress	Supply diffusers dirty	119	custodial	Yes
FXXGES2019000FCA	Tight seal on ceiling tiles		199 Art Room	custodial	Yes
FXXGES2019000FCC	Tight seal on ceiling tiles		199 Art Room	custodial	Yes
FXXGES2019000FCD	Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress	Supply diffusers dirty	121	custodial	Yes
FXXGES2019000FCF	Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress	Returns in kitchen and kitchen storage dusty	107	custodial	Yes
FXXGES2019000FD1	Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress	Returns dirty	103	custodial	Yes
FXXGES2019000FD3	Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress		197 3rd Gr Closet	custodial	Yes
FXXGES2019000FD4	Miscellaneous finding	Bathroom exhaust not working	125	building	No
FXXGES2019000FD6	Tight seal on ceiling tiles		129	custodial	Yes
FXXGES2019000FD7	Miscellaneous finding	Bathroom exhaust not working	129	building	No
FXXGES2019000FDA	Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress	Supply diffusers dusty	137	custodial	Yes
FXXGES2019000FDC	Appliances (toaster/coffee maker/fridge/space heaters/air cleaners other than HEPA)		137	administration	Yes
FXXGES2019000FDD	Tight seal on ceiling tiles		Conference Room	custodial	Yes
FXXGES2019000FDE	Appliances (toaster/coffee maker/fridge/space heaters/air cleaners other than HEPA)		211	administration	Yes

Tracking Number	Finding Type	Comments	Location	Assigned To	Closed
FXXGES2019000FDF	Tight seal on ceiling tiles		4th grade pod	custodial	Yes
FXXGES2019000FE0	Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress	Supply diffusers dirty	162	custodial	Yes
FXXGES2019000FE2	Appliances (toaster/coffee maker/fridge/space heaters/air cleaners other than HEPA)		165	administration	Yes
FXXGES2019000FE3	Excessive stuffed animals		169	administration	Yes
FXXGES2019000FE4	Miscellaneous finding	Missing thermostat covers	Portable 1 and 2	building	No
FXXGES2019000FE6	Exterior doors not fully sealed (daylight)	Port 150 daylight at exterior doors	GT Portable	building	No
FXXGES2019000FE8	Miscellaneous finding	Missing thermostat cover	GT Portable	building	No
FXXGES2019000FEA	Tight seal on ceiling tiles		Quiet Room	custodial	Yes
FXXGES2019000FEB	Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress	Vent is loud and rattles	Quiet Room	building	No
FXXGES2019000FEC	Miscellaneous finding	Missing brick on backside of building	Exterior	building	No