

# Findings for walkthrough Oakland Mills High School: April 24th, 2019 (WXOMHS20190001A5)

Tracking Number	Finding Type	Comments	Location	Assigned To	Closed
FXOMHS2019001023	Tight seal on ceiling tiles	Stained ceiling tile center of room	801	custodial	Yes
FXOMHS2019001024	Tight seal on ceiling tiles	Stained tile near window	801	custodial	Yes
FXOMHS2019001027	Electrical cords unsecured, extend across walkways, cord protectors not installed	Need a cover for electrical cord	605	administration	Yes
FXOMHS2019001028	Signs of insects or evidence of pest		511	building	No
FXOMHS2019001029	Miscellaneous finding	Many boxes stacked up on the floor	802	administration	Yes
FXOMHS201900102B	General Cleanliness/Dust	Dust on vents	802	custodial	Yes
FXOMHS201900102F	Tight seal on ceiling tiles		509	custodial	Yes
FXOMHS2019001030	Miscellaneous finding	Sinks need to be sealed	Science back room	building	No
FXOMHS2019001032	Tight seal on ceiling tiles		509_hall	custodial	Yes
FXOMHS2019001033	General Cleanliness/Dust	Dust in air vents	804	custodial	Yes
FXOMHS2019001035	General Cleanliness/Dust		707	custodial	Yes
FXOMHS2019001036	General Cleanliness/Dust		Commons back of stage	custodial	Yes
FXOMHS2019001037	Tight seal on ceiling tiles	Sagging tiles and one stained	805	custodial	Yes
FXOMHS2019001038	Tight seal on ceiling tiles		507	custodial	Yes
FXOMHS201900103A	Miscellaneous finding	Valve sticking out of wall, could be a hazard Goggle cabinet broken	805	building	No
FXOMHS201900103C	Tight seal on ceiling tiles		505	custodial	Yes
FXOMHS201900103E	General Cleanliness/Dust	Dust in vents	807	custodial	Yes
FXOMHS2019001040	Tight seal on ceiling tiles		709	custodial	Yes
FXOMHS2019001042	Tight seal on ceiling tiles	Damaged ceiling tiles	807	custodial	Yes

Tracking Number	Finding Type	Comments	Location	Assigned To	Closed
FXOMHS2019001044	Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress		Media	custodial	Yes
FXOMHS2019001045	Plumbing fixture leaking/draining slowly		Restroom in life skills	custodial	Yes
FXOMHS2019001046	Signs of insects or evidence of pest		520	building	No
FXOMHS2019001047	Tight seal on ceiling tiles	Several stained tiles	306	custodial	Yes
FXOMHS2019001049	Electrical cords unsecured, extend across walkways, cord protectors not installed		306	administration	Yes
FXOMHS201900104A	Tight seal on ceiling tiles		Storage 709	custodial	Yes
FXOMHS201900104C	Plumbing fixture leaking/draining slowly		Bathroom men's by 409	custodial	Yes
FXOMHS201900104E	Miscellaneous finding	Power along back wall cuts out on occasion	305	building	No
FXOMHS2019001050	Plumbing fixture leaking/draining slowly		Women's bathroom	custodial	Yes
FXOMHS2019001051	Electrical cords unsecured, extend across walkways, cord protectors not installed		304	administration	Yes
FXOMHS2019001052	Tight seal on ceiling tiles	Several stained tiles	303	custodial	Yes
FXOMHS2019001054	Electrical cords unsecured, extend across walkways, cord protectors not installed		303	administration	Yes
FXOMHS2019001055	Tight seal on ceiling tiles		401_hall	custodial	Yes
FXOMHS2019001056	General Cleanliness/Dust		620	administration	Yes
FXOMHS2019001057	Tight seal on ceiling tiles		Gym hallway	custodial	Yes
FXOMHS2019001058	Electrical cords unsecured, extend across walkways, cord protectors not installed		310	administration	Yes
FXOMHS2019001059	Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress		gym	custodial	Yes
FXOMHS201900105A	General Cleanliness/Dust	Dust in vents	310	custodial	Yes
FXOMHS201900105C	Tight seal on ceiling tiles	Broken tiles	308	custodial	Yes
FXOMHS201900105E	Tight seal on ceiling tiles		600	custodial	Yes

Tracking Number	Finding Type	Comments	Location	Assigned To	Closed
FXOMHS201900105F	Electrical cords unsecured, extend across walkways, cord protectors not installed		308	administration	Yes
FXOMHS2019001060	Tight seal on ceiling tiles	Stained ceiling tile	309	custodial	Yes
FXOMHS2019001062	Signs of insects or evidence of pest		Storage	building	No
FXOMHS2019001063	Tight seal on ceiling tiles		Storage	custodial	Yes
FXOMHS2019001064	General Cleanliness/Dust		Storage 2	custodial	Yes
FXOMHS2019001065	General Cleanliness/Dust		Storage	custodial	Yes
FXOMHS2019001066	Electrical cords unsecured, extend across walkways, cord protectors not installed		301	administration	Yes
FXOMHS2019001067	Exterior doors not fully sealed (daylight)		Aux. gym	building	No
FXOMHS2019001068	Signs of insects or evidence of pest		Storage	building	No
FXOMHS2019001069	General Cleanliness/Dust		Storage	custodial	Yes
FXOMHS201900106A	Tight seal on ceiling tiles		609	custodial	Yes
FXOMHS201900106B	Electrical cords unsecured, extend across walkways, cord protectors not installed		609	administration	Yes
FXOMHS201900106E	Electrical cords unsecured, extend across walkways, cord protectors not installed		209	administration	Yes
FXOMHS201900106F	Tight seal on ceiling tiles	Sagging tiles	209	custodial	Yes
FXOMHS2019001071	Tight seal on ceiling tiles		Weight room hallway	custodial	Yes
FXOMHS2019001072	Tight seal on ceiling tiles	Stained tiles	208	custodial	Yes
FXOMHS2019001073	Tight seal on ceiling tiles		705	custodial	Yes
FXOMHS2019001075	Exterior doors not fully sealed (daylight)		Weightroom	building	No
FXOMHS2019001076	Electrical cords unsecured, extend across walkways, cord protectors not installed		208	administration	Yes
FXOMHS2019001077	Tight seal on ceiling tiles		Weightroom	custodial	Yes
FXOMHS2019001078	Electrical cords unsecured, extend across walkways, cord protectors not installed		211	administration	Yes

Tracking Number	Finding Type	Comments	Location	Assigned To	Closed
FXOMHS2019001079	Electrical cords unsecured, extend across walkways, cord protectors not installed		Journalism	administration	Yes
FXOMHS201900107A	General Cleanliness/Dust		704	custodial	Yes
FXOMHS201900107C	Signs of insects or evidence of pest		Baseball storage	building	No
FXOMHS201900107D	General Cleanliness/Dust		701	custodial	Yes
FXOMHS201900107E	Tight seal on ceiling tiles		Gray room	custodial	Yes
FXOMHS201900107F	Tight seal on ceiling tiles		400	custodial	Yes
FXOMHS2019001081	Tight seal on ceiling tiles		407	custodial	Yes
FXOMHS2019001082	Tight seal on ceiling tiles		403	custodial	Yes
FXOMHS2019001083	Signs of insects or evidence of pest	Ants coming in from window	100	building	No
FXOMHS2019001085	Electrical cords unsecured, extend across walkways, cord protectors not installed		411	administration	Yes
FXOMHS2019001086	Miscellaneous finding	Poor houskeeping	Custodial closet	custodial	Yes
FXOMHS2019001088	Electrical cords unsecured, extend across walkways, cord protectors not installed		108	administration	Yes
FXOMHS201900108A	Tight seal on ceiling tiles		Storage	custodial	Yes
FXOMHS201900108B	Tight seal on ceiling tiles		404	custodial	Yes
FXOMHS201900108D	Tight seal on ceiling tiles		101	custodial	Yes
FXOMHS201900108E	Signs of insects or evidence of pest	Ants	101	building	No
FXOMHS2019001090	Electrical cords unsecured, extend across walkways, cord protectors not installed		102	administration	Yes
FXOMHS2019001091	Floor coverings not level or secure (tile, carpets, wood board, etc.)	Generally dirty	103	custodial	Yes
FXOMHS2019001093	Electrical outlets not secured, cover missing, frayed wires on equipment	Fixture broken on ceiling	106	building	No
FXOMHS2019001095	Electrical cords unsecured, extend across walkways, cord protectors not installed		106	administration	Yes
FXOMHS2019001097	Electrical cords unsecured, extend across walkways, cord protectors not installed		105	administration	Yes

Tracking Number	Finding Type	Comments	Location	Assigned To	Closed
FXOMHS2019001098	Electrical cords unsecured, extend across walkways, cord protectors not installed		408	administration	Yes
FXOMHS201900109B	Electrical cords unsecured, extend across walkways, cord protectors not installed		104	administration	Yes
FXOMHS201900109C	Tight seal on ceiling tiles		212_hall	custodial	Yes
FXOMHS201900109D	Electrical cords unsecured, extend across walkways, cord protectors not installed		204	administration	Yes
FXOMHS201900109E	Electrical cords unsecured, extend across walkways, cord protectors not installed		212	administration	Yes
FXOMHS201900109F	Uncomfortable temperature		207	building	No
FXOMHS20190010A0	Electrical cords unsecured, extend across walkways, cord protectors not installed		207	administration	Yes
FXOMHS20190010A1	Uncomfortable temperature		206	building	No
FXOMHS20190010A2	Electrical cords unsecured, extend across walkways, cord protectors not installed		206	administration	Yes
FXOMHS20190010A3	Tight seal on ceiling tiles		303_hall	custodial	Yes
FXOMHS20190010A4	Tight seal on ceiling tiles		Hallway	custodial	Yes
FXOMHS20190010A5	General Cleanliness/Dust		Hallway	custodial	Yes
FXOMHS20190010A6	Tight seal on ceiling tiles	Stained tile on closet	Athletics Manager Office	custodial	Yes
FXOMHS20190010A8	General Cleanliness/Dust	Area under sink should be cleaned	Conf Room off mediA	custodial	Yes
FXOMHS20190010AA	Appliances (toaster/coffee maker/fridge/space heaters/air cleaners other than HEPA)	Fan	office off Media	administration	Yes
FXOMHS20190010AC	Tight seal on ceiling tiles	Ceiling panel not all the way against ceiling, accumulating dirt	Men's Bath near cafe	custodial	Yes
FXOMHS20190010AE	Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress		Conf Room	custodial	Yes
FXOMHS20190010AF	Tight seal on ceiling tiles		104	custodial	Yes

<b>Tracking Number</b>	<b>Finding Type</b>	<b>Comments</b>	<b>Location</b>	<b>Assigned To</b>	<b>Closed</b>
FXOMHS20190010B0	Miscellaneous finding	Housekeeping very poor	Stage Craft	administration	Yes
FXOMHS20190010B2	Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress	Supply Diffusers dirty	Student Serices	administration	Yes
FXOMHS20190010B4	Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress		040	administration	Yes
FXOMHS20190010B5	Appliances (toaster/coffee maker/fridge/space heaters/air cleaners other than HEPA)		Student Services Her - Mb	administration	Yes
FXOMHS20190010B6	Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress		210_hall	administration	Yes
FXOMHS20190010B7	General Cleanliness/Dust	Hot tub very dirty	Ice Room	custodial	Yes