

Findings for walkthrough Worthington Elementary School: April 25th, 2019 (WXWOES20190001A6)

Tracking Number	Finding Type	Comments	Location	Assigned To	Closed
FXWOES20190010B8	Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress	Supplies dirty (high dusting)	184_cafeteria	custodial	Yes
FXWOES20190010BA	Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress	Returns near stage slightly dirty	184	custodial	Yes
FXWOES20190010BC	General Cleanliness/Dust		193	custodial	Yes
FXWOES20190010BD	Tight seal on ceiling tiles	Stain over closet Stain by air vent	120	custodial	Yes
FXWOES20190010C1	Plumbing fixture leaking/draining slowly	Teacher indicated carpet gets wet on rainy days	196	environmental	Yes
FXWOES20190010C3	Tight seal on ceiling tiles		125	custodial	Yes
FXWOES20190010C4	Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress	Gym Storage - supply diffusers dirty	199b	custodial	Yes
FXWOES20190010C6	Tight seal on ceiling tiles	Hole in tile	Gym Storage across from gym	custodial	Yes
FXWOES20190010C8	Excessive stuffed animals		129	administration	Yes
FXWOES20190010C9	Appliances (toaster/coffee maker/fridge/space heaters/air cleaners other than HEPA)		129	administration	Yes
FXWOES20190010CA	Appliances (toaster/coffee maker/fridge/space heaters/air cleaners other than HEPA)		132	administration	Yes
FXWOES20190010CB	Uncomfortable temperature		131	building	No
FXWOES20190010CC	Artificial plants/trees		134	administration	Yes
FXWOES20190010CE	Appliances (toaster/coffee maker/fridge/space heaters/air cleaners other than HEPA)		135	administration	Yes
FXWOES20190010CF	Tight seal on ceiling tiles	Stained tile in closet	191	custodial	Yes

Tracking Number	Finding Type	Comments	Location	Assigned To	Closed
FXWOES20190010D1	Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress	Supply diffuser dirty	104	custodial	Yes
FXWOES20190010D3	Artificial plants/trees		142	administration	Yes
FXWOES20190010D4	Exterior doors not fully sealed (daylight)		142	building	No
FXWOES20190010D5	Appliances (toaster/coffee maker/fridge/space heaters/air cleaners other than HEPA)		143	administration	Yes
FXWOES20190010D6	Tight seal on ceiling tiles	Loose tile	102	custodial	Yes
FXWOES20190010D8	Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress		105	custodial	Yes
FXWOES20190010D9	Miscellaneous finding	Counter tops need corking	108	building	No
FXWOES20190010DB	Tight seal on ceiling tiles		155 B	custodial	Yes
FXWOES20190010DC	Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress		155	custodial	Yes
FXWOES20190010DD	Tight seal on ceiling tiles	2 tiles missing, need to be cut	156	building	No
FXWOES20190010DF	Tight seal on ceiling tiles		169	custodial	Yes
FXWOES20190010E0	Miscellaneous finding	2 lights out	183	custodial	Yes
FXWOES20190010E2	General Cleanliness/Dust	Room cluttered	177	administration	Yes
FXWOES20190010E4	Appliances (toaster/coffee maker/fridge/space heaters/air cleaners other than HEPA)	Heater	177	administration	Yes