

# Findings for walkthrough Wilde Lake High School: August 5th, 2019

## (WXWLHS20190001E8)

Tracking Number	Finding Type	Comments	Location	Assigned To	Closed
FXWLHS201900119A	Visible mold on surfaces due to elevated relative humidity/dew point		Cafeteria	building	Yes