

# Findings for walkthrough Bollman Bridge Elementary School: August 22nd, 2019

## (WXBBES20190001EF)

Tracking Number	Finding Type	Comments	Location	Assigned To	Closed
FXBBES20190011A0	Visible mold on surfaces due to elevated relative humidity/dew point		Gym Office	administration	Yes
FXBBES20190011A1	Visible mold on surfaces due to elevated relative humidity/dew point		Gym Office	custodial	Yes