

# Findings for walkthrough Thomas Viaduct Middle School: October 18th, 2019

## (WXTVMS201900021E)

Tracking Number	Finding Type	Comments	Location	Assigned To	Closed
FXTVMS2019001219	General Cleanliness/Dust		a28	custodial	Yes
FXTVMS201900121A	Tight seal on ceiling tiles		207	custodial	Yes
FXTVMS201900121B	General Cleanliness/Dust		a31	custodial	Yes
FXTVMS201900121C	Tight seal on ceiling tiles	Water stain near light	207	custodial	Yes
FXTVMS201900121E	Artificial plants/trees	Plants need trays	205	administration	Yes
FXTVMS201900121F	Miscellaneous finding	Conduit open on floor. Storage too close to circuit breakers	a36	building	Yes
FXTVMS2019001220	General Cleanliness/Dust	Dusty bookcase	39	custodial	Yes
FXTVMS2019001221	General Cleanliness/Dust	Dusty bookcases	a40	custodial	Yes
FXTVMS2019001222	General Cleanliness/Dust	Dusty furniture and bookcases	a49	custodial	Yes
FXTVMS2019001223	General Cleanliness/Dust	Dusty bookcases	a48	custodial	Yes
FXTVMS2019001224	Tight seal on ceiling tiles	Stained ceiling tile	242 stairwell	custodial	Yes
FXTVMS2019001225	Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress	Dusty	a47	custodial	Yes
FXTVMS2019001226	Miscellaneous finding	Upper right wall gap by ceiling tiles	a56	building	Yes
FXTVMS2019001227	Tight seal on ceiling tiles		a56	custodial	Yes
FXTVMS2019001228	Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress		a56	custodial	Yes
FXTVMS2019001229	Miscellaneous finding	Open ended piping under sink in front f room	a56	building	Yes
FXTVMS201900122A	Miscellaneous finding	Desks stored in electrical closet 229	229	administration	Yes
FXTVMS201900122B	General Cleanliness/Dust	Dirty lunch container - trash on counter	a57	administration	Yes
FXTVMS201900122C	Miscellaneous finding	Clean out without a cover	a53	building	Yes
FXTVMS201900122D	Miscellaneous finding	Teacher demo desk pipes under sink	a60	building	Yes

Tracking Number	Finding Type	Comments	Location	Assigned To	Closed
FXTVMS201900122F	General Cleanliness/Dust	Open food package	a67	administration	Yes
FXTVMS2019001230	Tight seal on ceiling tiles		A72	custodial	Yes
FXTVMS2019001231	Miscellaneous finding	Sprinkler blocked	a69	administration	Yes
FXTVMS2019001232	Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress		a68	custodial	Yes
FXTVMS2019001233	General Cleanliness/Dust	Dusty bookcases	a66	custodial	Yes
FXTVMS2019001235	General Cleanliness/Dust		b21	custodial	Yes
FXTVMS2019001237	General Cleanliness/Dust		b20	custodial	Yes
FXTVMS2019001238	General Cleanliness/Dust		b06	custodial	Yes
FXTVMS2019001239	General Cleanliness/Dust		b05	custodial	Yes
FXTVMS201900123A	General Cleanliness/Dust		b05	custodial	Yes
FXTVMS201900123B	General Cleanliness/Dust		b21	custodial	Yes
FXTVMS201900123D	Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress	Dusty vent and spots on tile in dishwasher room,vent over food line on right dusty, tile falling out in middle of kitchen,hood vents dusty	b28	custodial	Yes
FXTVMS201900123E	Tight seal on ceiling tiles	Missing and one out of place	b33	custodial	Yes
FXTVMS201900123F	Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress	Wall return grille dirty	b06	custodial	Yes
FXTVMS2019001240	Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress	Wall vent dirty. This finding applies to supply diffusers and return grilles throughout school	b05	custodial	Yes
FXTVMS2019001241	Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress	All oven vents dirty	b03	custodial	Yes
FXTVMS2019001242	Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress	Two vents in back dirty	b60	custodial	Yes
FXTVMS2019001243	Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress		Girls Locker Room	custodial	Yes
FXTVMS2019001244	Miscellaneous finding	B48 baseboard coming off near door to outside	Girls Locker Room	building	Yes

Tracking Number	Finding Type	Comments	Location	Assigned To	Closed
FXTVMS2019001245	Exterior doors not fully sealed (daylight)	B48 light from bottom of door that leads to outdoors	Girls Locker Room	building	Yes