

Findings for walkthrough River Hill High School: October 23rd, 2019 (WXRHHS2019000232)

Tracking Number	Finding Type	Comments	Location	Assigned To	Closed
FXRHHS2019001278	Tight seal on ceiling tiles		117	custodial	Yes
FXRHHS2019001279	Tight seal on ceiling tiles		223a	custodial	Yes
FXRHHS201900127A	General Cleanliness/Dust		222	custodial	Yes
FXRHHS201900127B	Floor coverings not level or secure (tile, carpets, wood board, etc.)		234	building	Yes
FXRHHS2019001333	Uncomfortable temperature	Over heating	235	building	Yes
FXRHHS2019001334	Tight seal on ceiling tiles	One ceiling tile slightly misplaced.	Copy Room	custodial	Yes
FXRHHS2019001335	Tight seal on ceiling tiles		242 Guidance Lobby	custodial	Yes
FXRHHS2019001336	Artificial plants/trees	Fake plants	Guidance	administration	Yes
FXRHHS2019001337	Miscellaneous finding	Need caulking around sink	bathroom in health room 230	building	Yes
FXRHHS2019001338	Electrical cords unsecured, extend across walkways, cord protectors not installed	Lots of plugs, wires, flashing lights, lava lamp, area rug, cables	Room 206B Blackman office	administration	Yes
FXRHHS2019001339	Miscellaneous finding	kitchen sponges at sink	206A Closet/Music	administration	Yes
FXRHHS201900133A	Miscellaneous finding	Cracks in walls between under blocks	207A Uniform Room	building	Yes
FXRHHS201900133B	Tight seal on ceiling tiles	one ceiling tile displaced with ceiling light falling slightly	216- Art Room	custodial	Yes
FXRHHS201900133C	Tight seal on ceiling tiles	One unusual ceiling tile and pen stuffed in the ceiling.	215 Art Room	custodial	Yes
FXRHHS201900133D	Tight seal on ceiling tiles	Weird stuff on ceiling near 2008 sign, multiple lights and ceiling lights with dust and brown stains,	cafeteria and cafeteria bump out	custodial	Yes
FXRHHS201900133E	Tight seal on ceiling tiles	ceiling tiles above wash sinks. several falling and bending	kitchen	custodial	Yes

Tracking Number	Finding Type	Comments	Location	Assigned To	Closed
FXRHHS201900133F	Electrical cords unsecured, extend across walkways, cord protectors not installed		248 B Lab	administration	Yes
FXRHHS2019001340	Miscellaneous finding	Shelf in front of fire alarm	Science Office	administration	Yes
FXRHHS2019001341	Miscellaneous finding	Wire net and wooden pillars. Things from home coming decoration.	131	administration	Yes
FXRHHS2019001342	Miscellaneous finding		132A	administration	Yes
FXRHHS2019001343	Electrical cords unsecured, extend across walkways, cord protectors not installed		136A	administration	Yes
FXRHHS2019001344	Tight seal on ceiling tiles		136 closet	custodial	Yes
FXRHHS2019001345	Miscellaneous finding	Clutter from homecoming. Two microwave and water dispenser	Plan C	administration	Yes
FXRHHS2019001346	General Cleanliness/Dust	Yellow stains on one sink	Girls Student bathroom	custodial	Yes
FXRHHS2019001347	Electrical outlets not secured, cover missing, frayed wires on equipment		137	administration	Yes
FXRHHS2019001363	Miscellaneous finding		Room 139	administration	Yes
FXRHHS2019001364	Electrical outlets not secured, cover missing, frayed wires on equipment		Room 139	administration	Yes
FXRHHS2019001365	Electrical cords unsecured, extend across walkways, cord protectors not installed		141	administration	Yes
FXRHHS2019001366	Miscellaneous finding	Old Chair	142	administration	Yes
FXRHHS2019001367	Miscellaneous finding		144	administration	Yes
FXRHHS2019001368	Miscellaneous finding	Coffee maker	146	administration	Yes
FXRHHS201900136A	Tight seal on ceiling tiles		151	custodial	Yes
FXRHHS201900136B	Electrical cords unsecured, extend across walkways, cord protectors not installed		153	administration	Yes
FXRHHS201900136C	Tight seal on ceiling tiles		154 closet left	custodial	Yes
FXRHHS201900136D	Miscellaneous finding	Hanging stuff from ceiling	155 Planning Area	administration	Yes
FXRHHS201900136E	Tight seal on ceiling tiles		Stairs near 151	custodial	Yes

Tracking Number	Finding Type	Comments	Location	Assigned To	Closed
FXRHHS201900136F	Miscellaneous finding	White stain on exterior wall.	Mini Theater	building	Yes
FXRHHS2019001371	Miscellaneous finding	Weather stripping at bottom of exterior doors (right side)	Auditorium	building	Yes
FXRHHS2019001372	Miscellaneous finding	Rusted and broken pipe insulation and water stain	Penthouse	building	Yes
FXRHHS2019001373	Miscellaneous finding	Dusty in storage room Tile stain by sprinkler in tool storage Dusty vent in tool storage	Science shop	custodial	Yes
FXRHHS2019001374	Tight seal on ceiling tiles		Hallway behind Auditorium outside f 5205	custodial	Yes
FXRHHS2019001375	Miscellaneous finding	Dirty vent in bathroom	205	custodial	Yes
FXRHHS2019001376	Tight seal on ceiling tiles	Cookie ovens and refrigerator	206	administration	Yes
FXRHHS2019001377	Tight seal on ceiling tiles	No escutchen on sprinkler	TV Studio	building	Yes
FXRHHS2019001378	Tight seal on ceiling tiles	Fake plants	Media Storage	custodial	Yes
FXRHHS2019001379	Miscellaneous finding	lamps, furniture, coffee maker, microwave, fan, stool	240	administration	Yes
FXRHHS201900137A	Appliances (toaster/coffee maker/fridge/space heaters/air cleaners other than HEPA)		238	administration	Yes
FXRHHS201900137B	Appliances (toaster/coffee maker/fridge/space heaters/air cleaners other than HEPA)		239	administration	Yes
FXRHHS201900137C	Appliances (toaster/coffee maker/fridge/space heaters/air cleaners other than HEPA)	high temperature	235	administration	Yes
FXRHHS201900137E	Miscellaneous finding	Light out in back Replace two ceiling tiles in front	lower ninth grade locker rooms s-123	custodial	Yes
FXRHHS201900137F	Miscellaneous finding	Floor tile in front of sink is cracked	lower ninth grade teachers lounge	administration	Yes
FXRHHS2019001380	Tight seal on ceiling tiles	Vents dirty on the inside	Hallway in front of girls & boys Bathroom	custodial	Yes
FXRHHS2019001381	Miscellaneous finding	Light cover dirty	Front of back stairwell near room 120	custodial	Yes
FXRHHS2019001382	Miscellaneous finding	Things stored in front of electrical panel.	Electrical Closet	administration	Yes

Tracking Number	Finding Type	Comments	Location	Assigned To	Closed
FXRHHS2019001383	Tight seal on ceiling tiles	Around sprinkler head	Fitness Lab	custodial	Yes
FXRHHS2019001384	Miscellaneous finding	Missing escutchen plate	Hallway in front of fitness lab	building	Yes
FXRHHS2019001385	Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress	Dusty vent in light storage & upstairs storage closet/prop room	Auditorium	custodial	Yes
FXRHHS2019001386	General Cleanliness/Dust	Paint in sink Sawdust at miter saw	Science Shop	administration	Yes
FXRHHS2019001387	Artificial plants/trees		Media Storage	administration	Yes
FXRHHS2019001388	Tight seal on ceiling tiles		240	custodial	Yes
FXRHHS2019001389	Elevated moisture per moisture meter	Mens rest room paint ceiling in front of light fixture (wall is brown).	Lower 9th Grade Teacher Lounge	building	Yes
FXRHHS201900138A	Excess dirt or moisture or obstructed or purposely placed obstruction indicating occupant distress	HVAC vent broken-teachers lounge	Lower 9th Grade Teacher Lounge	building	Yes