

Findings for walkthrough Murray Hill Middle School: November 12th, 2019 (WXMHMS201900024B)

| Tracking Number | Finding Type | Comments | Location | Assigned To | Closed |
|------------------|---|--|--|----------------|--------|
| FXMHMS2019001487 | Tight seal on ceiling tiles | | gym | custodial | Yes |
| FXMHMS2019001488 | Uncomfortable temperature | HVAC units turned off because it gets too hot in the room. HVAC tech comes in and fixes it but few days later it gets uncomfortable again. | 105 | building | No |
| FXMHMS2019001489 | Appliances (toaster/coffee maker/fridge/space heaters/air cleaners other than HEPA) | Microwave and refrigerator | 120 | administration | Yes |
| FXMHMS201900148A | General Cleanliness/Dust | Dust and spiderwebs in upper windowsills | 120 | custodial | Yes |
| FXMHMS201900148B | Excessive stuffed animals | | 216 | administration | Yes |
| FXMHMS201900148C | Tight seal on ceiling tiles | Stained ceiling tile near light | 107 | custodial | Yes |
| FXMHMS201900148D | Chemicals are capped | Maintain 18 inches clearance from the ceiling | 216_closet | | No |
| FXMHMS201900148E | Plumbing fixture leaking/draining slowly | Middle faucet does not turn off all the way | Restroom | building | No |
| FXMHMS201900148F | Appliances (toaster/coffee maker/fridge/space heaters/air cleaners other than HEPA) | Microwave and electric equipment | Closet | administration | Yes |
| FXMHMS2019001490 | Artificial plants/trees | | 203 | administration | Yes |
| FXMHMS2019001491 | Uncomfortable temperature | HVAC units turned off because it gets too hot in the room. HVAC tech comes in and fixes it but few days later it gets uncomfortable again. | 205 | building | No |
| FXMHMS2019001492 | Miscellaneous finding | Blocking electrical panels | Electrical closet on second floor next Boys Room | administration | Yes |
| FXMHMS201900149C | Uncomfortable temperature | Window open & HVAC units turned off because it gets too hot in the room. HVAC tech comes in and fixes it but few days later it gets uncomfortable again. | 215 | building | No |

| Tracking Number | Finding Type | Comments | Location | Assigned To | Closed |
|------------------|---------------------------|--|----------|-------------|--------|
| FXMHMS201900149D | Uncomfortable temperature | HVAC units turned off because it gets too hot in the room. HVAC tech comes in and fixes it but few days later it gets uncomfortable again. | 203 | building | No |